

---

# **Nova Scotia Utility and Review Board**

**IN THE MATTER OF** *The Public Utilities Act*, R.S.N.S. 1989, c.380, as amended

## **2021 10-Year System Outlook**

### **NS Power**

June 30, 2021

**NON-CONFIDENTIAL**

---

**2021 10-Year System Outlook  
NON-CONFIDENTIAL**

---

TABLE OF CONTENTS

1		
2		
3	1.0	INTRODUCTION ..... 5
4	2.0	LOAD FORECAST..... 7
5	3.0	GENERATION RESOURCES..... 11
6	3.1	Existing Generation Resources ..... 11
7	3.1.1	Maximum Unit Capacity Rating Adjustments..... 13
8	3.1.2	Mersey Hydro ..... 14
9	3.1.3	Wreck Cove Hydro ..... 15
10	3.2	Changes in Capacity ..... 16
11	3.2.1	2020 IRP ..... 17
12	3.2.2	Victoria Junction Combustion Turbine..... 18
13	3.2.3	Annapolis Tidal..... 19
14	3.3	Unit Utilization Forecast..... 19
15	3.3.1	Evolution of the Energy Mix in Nova Scotia..... 19
16	3.3.2	Projections of Unit Utilization ..... 21
17	3.3.3	Steam Fleet Retirement Outlook..... 23
18	4.0	NEW SUPPLY SIDE FACILITIES ..... 28
19	5.0	QUEUED SYSTEM IMPACT STUDIES..... 29
20	5.1	OATT Transmission Service Queue..... 30
21	6.0	ENVIRONMENTAL AND EMISSIONS REGULATORY REQUIREMENTS ..... 32
22	6.1	Renewable Electricity Requirements ..... 32
23	6.2	Environmental Regulatory Requirements..... 35
24	6.3	Anticipated Policy Changes ..... 39
25	7.0	RESOURCE ADEQUACY ..... 41
26	7.1	Operating Reserve Criteria..... 41
27	7.2	Planning Reserve Criteria ..... 42
28	7.3	Capacity Contribution of Renewable Resources in Nova Scotia..... 45
29	7.3.1	Energy Resource Interconnection Service Connected Resources..... 46
30	7.4	Load and Resources Review ..... 47
31	8.0	TRANSMISSION PLANNING ..... 50

**2021 10-Year System Outlook  
NON-CONFIDENTIAL**

---

32	8.1	System Description .....	50
33	8.2	Transmission Design Criteria.....	51
34	8.2.1	Bulk Power System (BPS).....	52
35	8.2.2	Bulk Electric System (BES).....	52
36	8.2.3	Special Protection Systems (SPS).....	53
37	8.2.4	NPCC Directory 1 Review.....	53
38	8.3	Transmission Life Extension .....	56
39	8.4	Transmission Project Approval.....	56
40	8.5	New Large load Customer Interconnection Requests.....	57
41	9.0	TRANSMISSION DEVELOPMENT 2020 to 2030 .....	58
42	9.1	Impact of Proposed Load Facilities .....	58
43	9.2	129H-Kearney Lake Relocation.....	59
44	9.3	Transmission Development Plans.....	60
45	9.4	Western Valley Transmission System – Phase II Study .....	62
46	10.0	PANDEMIC RESPONSE.....	63
47	11.0	CONCLUSION.....	64
48			

**2021 10-Year System Outlook  
NON-CONFIDENTIAL**

---

**TABLE OF FIGURES**

1

2

3 Figure 1: Net System Requirement with Future DSM Program Effects (actuals are not weather adjusted) 8

4 Figure 2: Coincident Peak Demand with Future DSM Program Effects ..... 9

5 Figure 3: 2021 Firm Generating Capability for NS Power and IPPs ..... 12

6 Figure 4: Firm Generating Capability for Wholesale Market Participants ..... 13

7 Figure 5: Firm Capacity Changes & DSM..... 16

8 Figure 6: Additions and Retirements as per the 2020 IRP Reference Plan (2.0C) ..... 17

9 Figure 7: 2005, 2020 Actual and 2023 Forecast Energy Mix ..... 20

10 Figure 8: Peak System Demand Trend ..... 21

11 Figure 9: NS Power Steam Fleet Unit Utilization Forecast ..... 22

12 Figure 10: Utilization Factor..... 24

13 Figure 11: Forecast Unit Utilization Factors..... 26

14 Figure 12: Forecast Annual Investment (in 2021\$) by Unit ..... 27

15 Figure 13: Combined Transmission & Distribution Advanced Stage Interconnection Queue as of June 18,

16 2021 ..... 29

17 Figure 14: Requests in the OATT Transmission Queue ..... 30

18 Figure 15: RES Compliance Forecast..... 34

19 Figure 16: Multi-year Greenhouse Gas Emission Limits ..... 35

20 Figure 17: Greenhouse Gas Free Allowances 2019-2022..... 36

21 Figure 18: Emissions (SO<sub>2</sub>, NO<sub>x</sub>, Hg) ..... 38

22 Figure 19: NS Power 10-Year Load and Resources Outlook ..... 49

23 Figure 20: NS Power Major Facilities in Service 2021 ..... 50

24

**2021 10-Year System Outlook  
NON-CONFIDENTIAL**

---

1 **1.0 INTRODUCTION**

2  
3 In accordance with the 3.4.2.1<sup>1</sup> Market Rule requirements, this Report provides the 10-Year  
4 System Outlook on behalf of the Nova Scotia Power System Operator (NSPSO) for 2021.

5  
6 The 2021 10-Year System Outlook Report contains the following information:

- 7
- 8 • A summary of the Nova Scotia Power Incorporated (NS Power, Company) load forecast  
9 and update on the Demand Side Management (DSM) forecast in Section 2.
  - 10 • A summary of generation expansion anticipated for facilities owned by NS Power and  
11 others in Sections 3-5. NS Power’s generation planning for existing facilities, including  
12 retirements as well as investments in upgrades, refurbishment or life extension and new  
13 generating facilities committed in accordance with previously approved NSPSO system  
14 plans.
  - 15 • A summary of environmental and emissions regulatory requirements, as well as forecast  
16 compliance in Section 6. This Section also includes projections of the level of renewable  
17 energy available and discusses anticipated policy changes.
  - 18 • A Resource Adequacy Assessment in Section 7.
  - 19 • A discussion of transmission planning considerations in Section 8.
  - 20 • Identification of transmission-related capital projects currently in the Transmission  
21 Development Plan in Section 9.
  - 22 • A discussion of NS Power’s ongoing COVID-19 pandemic response in Section 10.
- 23

---

<sup>1</sup> Nova Scotia Wholesale and Renewable to Retail Electricity Market Rules (as amended 2016 06 10), Market Rule 3.4.2 states, “The NSPSO system plan will address: (a) transmission investment planning; (b) DSM programs operated by EfficiencyOne or others; (c) NS Power generation planning for existing Facilities, including retirements as well as investments in upgrades, refurbishment or life extension; (d) new Generating Facilities committed in accordance with previous approved NSPSO system plans; (e) new Generating Facilities planned by Market Participants or Connection Applicants other than NS Power; and (f) requirements for additional DSM programs and / or generating capability (for energy or ancillary services).”

**2021 10-Year System Outlook**  
**NON-CONFIDENTIAL**

---

1 As discussed in Section 7.4, the Company's 2020 Integrated Resource Plan (2020 IRP) evaluated  
2 a robust set of future planning scenarios, with modeling assumptions that were created  
3 incorporating significant stakeholder input. The 2020 IRP documented capacity  
4 expansion/retirement modeling optimization results and associated insights over a 25-year  
5 planning horizon (2021-2045). The reference plan from the 2020 IRP (Scenario 2.0C) forms the  
6 planning basis for the 2021 10-Year System Outlook. For energy forecasting purposes, updated  
7 PLEXOS modeling for the initial three years 2022-2024 was completed and the reference plan from  
8 the 2020 IRP (Scenario 2.0C) provides the data for the period 2025-2031. Recently announced  
9 federal and provincial policy statements discussed in Section 6.3 have the potential to impact the  
10 future of the Company's thermal generation fleet if such statements become legislative and/or  
11 regulatory requirements. NS Power continues to monitor and evaluate such developments and to  
12 the extent they become law, NS Power will incorporate them into its planning studies and reflect  
13 them in future 10 Year-System Outlook Reports.

14  
15 As discussed in Section 10, NS Power continues to monitor the ongoing COVID-19 pandemic and  
16 remains focused on the health and safety of employees, consultants, contractors, and their  
17 families. A response team is monitoring the situation, coordinating with authorities, and keeping  
18 employees informed via regular business updates. The economic effects of the COVID-19  
19 pandemic and their impact on short and medium-term system planning continue to be evaluated.

20

1   **2.0   LOAD FORECAST**

2  
3   The NS Power load forecast provides an outlook on the energy and peak demand requirements of  
4   customers in the province. The load forecast forms the basis for fuel supply planning, investment  
5   planning, and overall operating activities of NS Power. The figures presented in this Report are  
6   the same as those filed with the NSUARB in the 2021 Load Forecast Report on April 30, 2021 and  
7   were developed using NS Power’s statistically adjusted end-use (SAE) model to forecast the  
8   residential and commercial rate classes. The residential and commercial SAE models are combined  
9   with an econometric-based industrial forecast and customer-specific forecasts for NS Power’s  
10   large customers to develop an energy forecast for the province, also referred to as the Net System  
11   Requirement (NSR).

12  
13   **Figure 1** shows historical and forecast NSR which includes in-province energy sales plus system  
14   losses. NSR is expected to grow slowly until 2024, driven by increased residential customer count,  
15   electric heating in the residential sector, and industrial growth. Over the long term, this expected  
16   growth will be offset by anticipated Demand Side Management (DSM) initiatives and natural  
17   energy efficiency improvements outside structured DSM programs, as well as increased behind-  
18   the-meter small scale solar installations, resulting in a reduction in overall load between 2025 and  
19   2031. The net result of these inputs is an annual average decline of 0.1 percent in NSR compared  
20   to a peak demand forecast that remains flat.

**2021 10-Year System Outlook  
NON-CONFIDENTIAL**

---

1 **Figure 1: Net System Requirement with Future DSM Program Effects (actuals are not**  
2 **weather adjusted)**

3

<b>Year</b>	<b>NSR (GWh)</b>	<b>Growth (%)</b>
2011	11,907	-2.1
2012	10,475	-12.0
2013	11,194	6.9
2014	11,037	-1.4
2015	11,099	0.6
2016	10,809	-2.6
2017	10,873	0.6
2018	11,250	3.5
2019	11,077	-1.5
2020	10,723	-3.2
2021*	11,039	3.0
2022*	11,005	-0.3
2023*	11,043	0.3
2024*	11,119	0.7
2025*	11,083	-0.3
2026*	11,047	-0.3
2027*	10,997	-0.5
2028*	10,974	-0.2
2029*	10,913	-0.5
2030*	10,876	-0.3
2031*	10,875	0.0

4 \*Forecast value

5  
6 NS Power also forecasts the peak hourly demand for future years. The total system peak  
7 is defined as the highest single hourly average demand experienced in a year. It includes  
8 both firm and interruptible loads. Due to the weather-sensitive load component in Nova  
9 Scotia, the total system peak occurs in the period from December through February.



**2021 10-Year System Outlook  
NON-CONFIDENTIAL**

The peak demand forecast is developed using end-use energy forecasts combined with peak-day weather conditions to generate monthly peak demand forecasts through an estimated monthly peak demand regression model. The peak contribution from large customer classes is calculated from historical coincident load factors for each of the rate classes. Peak savings related to Demand Reduction (DR) activities, adjusted for Effective Load Carrying Capacity (ELCC) as outlined in the 2020 IRP and including critical peak pricing and direct control components, are included in the firm peak. After accounting for the effects of DSM savings, system peak is expected to remain essentially flat on average over the forecast period.

**Figure 2** shows the historical and forecast net system peak.

**Figure 2: Coincident Peak Demand with Future DSM Program Effects**

Year	Interruptible Contribution to Peak (MW)	Demand Response (reduction in Firm Peak only, MW)	Firm Contribution to Peak (MW)	System Peak (MW)	Growth (%)
2011	265	-	1,903	2,168	2.5
2012	141	-	1,740	1,882	-13.2
2013	136	-	1,897	2,033	8.0
2014	83	-	2,036	2,118	4.2
2015	141	-	1,874	2,015	-4.9
2016	98	-	2,013	2,111	4.8
2017	67	-	1,951	2,018	-4.4
2018	80	-	1,993	2,073	2.7
2019	111	-	1,949	2,060	-0.6
2020	96	-	1,954	2,050	-0.5
2021*	155	-	2,073	2,228	8.6
2022*	158	-4	2,062	2,225	-0.1
2023*	162	-12	2,065	2,240	0.7
2024*	162	-24	2,060	2,247	0.3
2025*	169	-36	2,053	2,257	0.5
2026*	170	-39	2,049	2,258	0.0
2027*	169	-39	2,046	2,254	-0.2
2028*	169	-39	2,044	2,251	-0.1
2029*	169	-38	2,044	2,251	0.0
2030*	168	-38	2,047	2,253	0.1
2031*	168	-37	2,057	2,262	0.4

\*Forecast value

**2021 10-Year System Outlook**  
**NON-CONFIDENTIAL**

---

1 As with any forecast, there is a degree of uncertainty around actual future outcomes. In electricity  
2 forecasting, much of this uncertainty is due to the impact of variations in weather, energy  
3 efficiency program effectiveness, the health of the economy, government policy regarding  
4 decarbonization, the impact of electrification, changes in large customer loads, the number of  
5 electric appliances and end-use equipment installed, and changes in technology.  
6

1   **3.0   GENERATION RESOURCES**

2  
3   **3.1   Existing Generation Resources**

4  
5       NS Power’s generation portfolio is composed of a mix of fuel and technology types that  
6       include coal, petroleum coke, light and heavy oil, natural gas, biomass, wind and hydro.  
7       In addition, NS Power purchases energy from Independent Power Producers (IPPs) located  
8       in the province and imports power across the NS Power/NB Power intertie and the  
9       Maritime Link. Since the implementation of the *Renewable Electricity Standards* (RES)  
10       discussed in Section 6.1, an increased percentage of total energy is produced by variable  
11       renewable resources such as wind. However, due to their intermittent nature, these variable  
12       resources provide less firm capacity than conventional generation resources. Therefore,  
13       the majority of the system requirement for firm capacity is met with NS Power’s  
14       conventional units (e.g. coal, gas) while their energy output is displaced by renewable  
15       resources when they are producing energy. This is discussed further in Section 3.3 below.

16  
17       **Figure 3** lists NS Power’s and the IPPs’ verified and forecast firm generating capability for  
18       generating stations/systems along with their fuel types up to the filing date of this Report.  
19       The changes and additions over the 10-year period to this total capacity are shown in  
20       **Figure 19** in Section 7.4.

**2021 10-Year System Outlook  
NON-CONFIDENTIAL**

**Figure 3: 2021 Firm Generating Capability for NS Power and IPPs**

Plant/System	Fuel Type	Winter Net Capacity <sup>2</sup> (MW)
Avon	Hydro	6.4
Black River	Hydro	21.4
Lequille System	Hydro	23.0
Bear River System	Hydro	35.5
Tusket	Hydro	2.3
Mersey System	Hydro	40.4
St. Margaret's Bay	Hydro	10.3
Sheet Harbour	Hydro	10.2
Dickie Brook	Hydro	3.6
Wreck Cove	Hydro	201.4
Annapolis Tidal <sup>3</sup>	Hydro	0.0
Fall River	Hydro	0.5
<b>Total Hydro</b>		<b>354.9</b>
Tufts Cove	Heavy Fuel Oil/Natural Gas	318
Trenton	Coal/Pet Coke/Heavy Fuel Oil	304
Point Tupper	Coal/Pet Coke/Heavy Fuel Oil	150
Lingan	Coal/Pet Coke/Heavy Fuel Oil	607
Point Aconi	Coal/Pet Coke & Limestone Sorbent (CFB)	168
<b>Total Steam</b>		<b>1547</b>
Tufts Cove Units 4, 5 & 6	Natural Gas	144
<b>Total Combined Cycle</b>		<b>144</b>
Burnside	Light Fuel Oil	132
Tusket	Light Fuel Oil	33
Victoria Junction <sup>4</sup>	Light Fuel Oil	66
<b>Total Combustion Turbine</b>		<b>231</b>

<sup>2</sup> Wind and Hydro are Effective Load Carrying Capability (ELCC) values. Please refer to Section 7.3 for further information.

<sup>3</sup> Annapolis is assumed to be out of service. Please refer to Section 3.2.3.

<sup>4</sup> Please refer to Section 3.2.2.

**2021 10-Year System Outlook  
NON-CONFIDENTIAL**

Plant/System	Fuel Type	Winter Net Capacity <sup>2</sup> (MW)
Pre-2001 Renewables	Independent Power Producers (IPPs)	25.8
Post-2001 Renewables (firm) <sup>5</sup>	IPPs	66.4
NS Power wind (firm) <sup>5</sup>	Wind	14.5
Community Feed-in Tariff (firm) <sup>5</sup>	IPPs	33.2
<b>Total IPPs &amp; Renewables</b>		<b>139.9</b>
<b>Total Capacity</b>		<b>2416.9</b>

**Figure 4: Firm Generating Capability for Wholesale Market Participants**

Wholesale Market Participant	Fuel Type	Winter Net Capacity <sup>6</sup> (MW)
Backup Top-Up (BUTU) <sup>7</sup>	Wind [Ellershouse <sup>8</sup> ]	4.2
Backup Top-Up (BUTU)	Import Contract <sup>9</sup>	0
<b>Total</b>		<b>4.2</b>

**3.1.1 Maximum Unit Capacity Rating Adjustments**

As a member of the Maritimes Area of the Northeast Power Coordinating Council (NPCC), NS Power meets the requirement for generator capacity verification as outlined in North American Electric Reliability Corporation (NERC) Standard *MOD-025-2 Verification and Data Reporting of Generator Real and Reactive*

<sup>5</sup> Energy Resource Interconnection Service (ERIS) and Network Resource Interconnection Service (NRIS) wind projects are assumed to have a firm capacity contribution of 18 percent as detailed in Section 7.3.1.

<sup>6</sup> Assuming 18 percent ELCC for wind and 0 percent for non-firm Imports to align with current NS Power planning practices. This matter is pending before the UARB.

<sup>7</sup> Wholesale Market Backup/Top-up Service (BUTU) Tariff participants currently include the Municipal load for Berwick, Mahone Bay, Antigonish and Riverport.

<sup>8</sup> Ellershouse wind farm owned by Alternative Resource Energy Authority (AREA).

<sup>9</sup> Import contract is currently delivered via the Nova Scotia/New Brunswick Intertie.

1            *Power Capability and Synchronous Condenser Reactive Power Capability*<sup>10</sup> which  
2            was approved by Federal Energy Regulatory Commission (FERC) on March 20,  
3            2014.

4  
5            The Net Operating Capacity of the thermal units and large hydro units covered by  
6            the NERC criteria do not require adjustments at this point. NS Power will continue  
7            to refresh unit maximum capacities in the 10-Year System Outlook each year as  
8            operational conditions change.

### 9 10           **3.1.2 Mersey Hydro**

11  
12           NS Power continues to assess options to address current concerns on the Mersey  
13           Hydro System. Degradation of the powerhouses and water control structures after  
14           nearly a century of service has necessitated the need for significant redevelopment  
15           work. The Mersey Hydro System is an important part of NS Power's hydro assets  
16           and is responsible for approximately 25 percent of annual domestic hydroelectric  
17           production. The Company is preparing a capital application for the redevelopment  
18           of the first phase of Mersey Hydro System, which is anticipated to include the  
19           replacement of the Big Falls Powerhouse, the Big Falls Control Structure and the  
20           redevelopment of the Big Falls Substation.

21  
22           The 2020 IRP completed an analysis on the redeveloping the Mersey system:<sup>11</sup>

23  
24           The Mersey Hydro system was analyzed during the Resource  
25           Screening phase of the IRP (described in Section 4.2.2) and  
26           economically retained, based on the assumptions developed from  
27           Nova Scotia Power's Hydro Asset Study (HAS). This resulted in the  
28           Mersey system being modeled as retained in all IRP key scenarios  
29           and sensitivities. However, due to the significant costs associated  
30           with redeveloping the Mersey system (as described in the HAS),

---

<sup>10</sup> <https://www.nerc.com/pa/Stand/Pages/Project2007-09-Generator-Verification.aspx>

<sup>11</sup> M08929, NS Power Integrated Resource Planning (IRP) Report, November 30, 2020, page 101.

1           IRP participants expressed a desire to examine the Mersey system  
2 specifically via a PLEXOS sensitivity.

3           //

4           The results of this sensitivity indicate that redevelopment of the  
5 Mersey system is economic relative to decommissioning when  
6 comparing the 25-year NPVRR with end effects. The sensitivity is  
7 shown to be equivalent to the base case in terms of relative rate  
8 impact, while the decommissioning sensitivity was indicated a  
9 lower cost under the shorter NPVRR metrics (25-year without end  
10 effects and 10-year NPVRR). Nova Scotia Power notes that these  
11 are very close results in all cases, particularly for a long-lived hydro  
12 asset like the Mersey system; accordingly, additional economic  
13 analysis will be provided in any capital applications for Mersey  
14 system refurbishment.  
15

### 16           **3.1.3 Wreck Cove Hydro**

17  
18           Wreck Cove Hydro is an important asset for NS Power, providing critical and  
19 renewable generation for peak demand periods. With the ability to quickly provide  
20 212 MW of peak capacity from two operating units and average annual generation  
21 of 300 GWh, Wreck Cove is NS Power's largest hydroelectric system. In 2020, NS  
22 Power submitted a capital application to the NSUARB to perform Life Extension  
23 & Modernization (LEM) work for the Wreck Cove Generating Station.<sup>12</sup> The Nova  
24 Scotia Utility and Review Board (NSUARB, Board) approved the proposed  
25 generator, turbine and spherical valve portion of work.<sup>13</sup> Specifically, as part of  
26 the LEM Project, the two unit turbines will be replaced with newly designed turbine  
27 runners which will have increased efficiency and a wider operating range over the  
28 existing ones. While the change in turbine runners will not change the peak capacity  
29 of 212 MW, it will provide a forecast increase of 5 percent to the annual generation  
30 from Wreck Cove. The completion of this project will bring the average annual  
31 generation at Wreck Cove to 315 GWh per year.

---

<sup>12</sup> M09596, NS Power Wreck Cove Life Extension and Modernization – Unit Rehabilitation and Replacement, CI 13838, February 28, 2020.

<sup>13</sup> M09596, NS Power Wreck Cove Life Extension and Modernization, NSUARB Order, February 2, 2021.

**2021 10-Year System Outlook  
NON-CONFIDENTIAL**

---

1 **3.2 Changes in Capacity**

2  
3 **Figure 5** provides the firm Supply and DSM capacity changes in accordance with the  
4 assumption set developed for the 2020 IRP and the 2021 Load Forecast.

5  
6 **Figure 5: Firm Capacity Changes & DSM**

7

New Resources 2022-2031	Net MW
DSM Peak reduction	290
Demand Response (Firm contribution) <sup>14</sup> programs	37
<b>Total Demand Side MW Change Projected Over Planning Period</b>	<b>327</b>
Biomass	43
Assumed Unit Retirements/Lay-ups <sup>15</sup>	-148
Maritime Link Import - Base Block	153
Tidal (Firm capacity)	6
IRP Reference Plan Additions:	
Firm imports over existing infrastructure	165
Battery	10
Natural Gas Units	259
New Wind Build (Firm capacity)	40
IRP Reference Plan Retirements:	
Trenton 5	-150
Tufts Cove 1 & 2	-171
Pt Aconi	-168
<b>Total Firm Supply MW Change Projected Over Planning Period</b>	<b>40</b>

8

---

<sup>14</sup> Represents the firm contribution of demand response programs in 2031 assuming an ELCC of 48 percent. Refer to Section 2.0, Figure 2 for the annual DR totals from 2022 to 2031.

<sup>15</sup> Retirement of Lingan 2 after the Maritime Link Base Block provides firm capacity service.

---



**2021 10-Year System Outlook  
NON-CONFIDENTIAL**

---

**3.2.1 2020 IRP**

The 2020 IRP evaluated resource plans that integrate more renewable energy and reflect a provincial decarbonization strategy over the next 25 years.<sup>16</sup> The 2020 IRP serves as a directional roadmap to guide future decision making; it is not prescriptive in nature. The 2020 IRP Reference Plan (2.0C) outlines changes to the resource mix that are representative of many common elements in the resource plans evaluated. However, the specific type, quantity and timing of future resource additions and retirements remains uncertain as several key actions arising from the 2020 IRP continue and further clarity and legislative direction is obtained in response to recent government policy announcements.

**Figure 6: Additions and Retirements as per the 2020 IRP Reference Plan (2.0C)**

<b>2020 IRP Reference Plan (2.0C)<sup>17</sup></b>		
	<b>Additions</b>	<b>Retirements</b>
<b>2022</b>	Firm import opportunities on existing transmission infrastructure (165 MW)	
<b>2023</b>	Reciprocating Engine (9.3 MW)	Trenton 5 (- 150 MW)
	Battery <sup>18</sup> (10 MW)	
<b>2024</b>		
<b>2025</b>		
<b>2026</b>	Combustion turbines (150 MW)	Tufts Cove 1 & 2 (- 171 MW)
<b>2027</b>		
<b>2028</b>		
<b>2029</b>		
<b>2030</b>	New Wind additions (Installed capacity 400 MW - Firm 40 MW based on marginal ELCC of 10%) <sup>19</sup>	Pt Aconi (- 168 MW)
	Combustion turbine (100 MW)	
<b>2031</b>		

---

<sup>16</sup> M08929, NS Power Integrated Resource Planning (IRP) Report , November 30, 2020

<sup>17</sup> Lingan 2 is assumed to be retired prior to 2022 in IRP Scenario 2.0C.

<sup>18</sup> Delayed from 2021 to 2023 due to lead times.

<sup>19</sup> See Section 7.3 for more on ELCC of new wind; verification of wind integration strategies via additional system studies will be completed as part of the IRP Action Plan.

1           **3.2.2 Victoria Junction Combustion Turbine**

2  
3           On March 23, 2020 the NSUARB issued its decision<sup>20</sup> to decline approval of the  
4           Company's capital application for the work related to the refurbishment of the  
5           Victoria Junction Unit 2 Combustion Turbine (VJ2). VJ2 is a 33 MW combustion  
6           turbine that provides black start capability, 10-minute reserve, Volt-Ampere  
7           Reactive support and additional firm capacity to the NS Power electrical system.  
8           In its decision, the NSUARB stated:

9  
10                       NS Power may re-apply following the completion of the review of  
11                       existing CT (oil) resources during the 2020 IRP proceeding or after  
12                       a comprehensive alternate analysis of all the Company's oil CTs has  
13                       been completed.

14  
15           The 2020 IRP included analysis which confirmed that existing combustion turbine  
16           resources provide economic benefit to customers and are economically sustained  
17           through the planning horizon with the modeled levels of sustaining capital  
18           investment.

19  
20           On May 25, 2021, NS Power resubmitted a capital application to the NSUARB<sup>21</sup>  
21           for the refurbishment of VJ2. For the purposes of this study, the Company has  
22           forecast the inclusion of the firm capacity provided by VJ2 in NS Power's resource  
23           mix.

---

<sup>20</sup> M09560, NSUARB letter to NS Power re Approval of 2020 Capital Work Order (P-520), March 23, 2020.

<sup>21</sup> M10129, NS Power Application for Approval of VJ2 Engine Refurbishment (P-128.20), May 25, 2021.

1           **3.2.3 Annapolis Tidal**

2  
3           Following the failure of a critical component of the Annapolis Tidal Generating  
4           Station NS Power has determined that the facility should be retired. In February  
5           2021 NS Power filed an application with the NSUARB<sup>22</sup> for approval of the  
6           accounting treatment of the unrecovered net book value of the assets. The  
7           application is currently before the NSUARB. For the purposes of the 10-Year  
8           System Outlook, NS Power has assumed no capacity contribution from the  
9           Annapolis Tidal Generating Station.

10  
11       **3.3 Unit Utilization Forecast**

12  
13       The Company typically forecasts 10 years of utilization and investment projections in this  
14       Report. There are many operational realities, such as the prices of fuel and power or  
15       changes in policy or regulation that could trigger a significant shift in the utilization  
16       forecast to provide the most economic system dispatch for customers.

17  
18       **3.3.1 Evolution of the Energy Mix in Nova Scotia**

19  
20       NS Power's energy production mix has undergone significant changes over the last  
21       15 years. Since the implementation of the *Renewable Electricity Standards* (RES),  
22       an increased percentage of energy sales is produced by variable renewable  
23       resources such as wind. However, due to their intermittent nature, variable  
24       resources provide less firm capacity than conventional generation resources.  
25       Therefore, the majority of the system requirement for firm capacity and other  
26       ancillary services is met with NS Power's conventional units (i.e. coal, gas, diesel,  
27       hydro) as discussed in Sections 3.1 and 3.2, while the energy output of conventional

---


<sup>22</sup> M10013, NS Power Application re Annapolis Tidal Generation Station Retirement: Request for Accounting Treatment and Net Book Value Recovery (P-111.6), February 22, 2021.

**2021 10-Year System Outlook**  
**NON-CONFIDENTIAL**

---

1 units is being displaced by renewable resources. **Figure 7**<sup>23</sup> below illustrates this  
2 change with the actual energy mix from 2005 and 2020 and the updated forecast  
3 for 2023.  
4

5 **Figure 7: 2005, 2020 Actual and 2023 Forecast Energy Mix**




6  
7  
8 As illustrated in **Figure 8**, NS Power’s historical firm peak demand has been  
9 increasing at an average rate of approximately 1 percent per year. After accounting  
10 for the effects of DSM savings, the system peak is expected to remain essentially  
11 flat on average over the forecast period. Future growth is expected to be mitigated  
12 through DSM, Demand Response strategies and underlying efficiency  
13 improvements. While energy is increasingly being produced by new renewable  
14 sources, the capacity required to serve system demand will largely continue to be  
15 served by dispatchable conventional resources together with firm imports. These  
16 resources also provide other critical services to the system such as load following.  
17

---

<sup>23</sup> Consistent with the provisions of the *Renewable Electricity Regulations*, in 2021 the category of Imports includes ML Surplus energy while the category of Hydro includes ML NS Base Block and Supplemental Energy from the Muskrat Falls hydro project.

---

1 **Figure 8: Peak System Demand Trend**



3  
4  
5 **3.3.2 Projections of Unit Utilization**

6  
7 The 2020 IRP provided an in-depth analysis of unit utilization. The reference plan  
8 from the 2020 IRP (Scenario 2.0C) forms the planning basis for the 2021 10-Year  
9 System Outlook. For energy forecasting purposes, updated PLEXOS modeling for  
10 the initial three years 2022-2024 was completed and the reference plan from the  
11 2020 IRP (Scenario 2.0C) provides the data for the period 2025-2031. As  
12 anticipated new legislation and regulations come into effect, the effect of these  
13 changes on unit utilization will be reflected, as appropriate, in future planning  
14 analyses. The three-year 2022-2024 update allowed updated assumptions regarding  
15 fuel and market prices, load forecast, system constraints and generating parameters  
16 to be reflected in this report.

**2021 10-Year System Outlook  
NON-CONFIDENTIAL**

Figure 9 below provides the current forecast unit utilization of NS Power’s steam fleet.

**Figure 9: NS Power Steam Fleet Unit Utilization Forecast**

		2022	2023	2024	2025	2026	2027	2028	2029	2030	2031
Lingan 1	Capacity Factor (%)	42	59	48	25	25	27	25	33	20	20
	Unit Cycles (Ranges)	< 10	< 10	< 10	10 - 25	10 - 25	10 - 25	10 - 25	25 - 50	10 - 25	10 - 25
	Service Hours	5555	8271	6468	3369	3359	3760	3359	4777	2564	2546
Lingan 2	Capacity Factor (%)	3	0	0	0	0	0	0	0	0	0
	Unit Cycles (Ranges)	< 10	0	0	0	0	0	0	0	0	0
	Service Hours	305	0	0	0	0	0	0	0	0	0
Lingan 3	Capacity Factor (%)	30	24	27	42	27	27	28	23	24	22
	Unit Cycles (Ranges)	10 - 25	10 - 25	10 - 25	25 - 50	50 - 100	25 - 50	50 - 100	25 - 50	25 - 50	25 - 50
	Service Hours	3665	2680	3493	6195	3820	3898	4131	3113	2979	2661
Lingan 4	Capacity Factor (%)	43	38	40	27	27	24	25	24	19	22
	Unit Cycles (Ranges)	10 - 25	10 - 25	10 - 25	10 - 25	10 - 25	10 - 25	25 - 50	25 - 50	25 - 50	10 - 25
	Service Hours	5796	4680	5049	3474	3356	3119	3279	3323	2452	2702
Point Aconi	Capacity Factor (%)	23	26	25	30	64	66	64	59	0	0
	Unit Cycles (Ranges)	< 10	< 10	< 10	< 10	< 10	< 10	< 10	< 10	0	0
	Service Hours	2860	2955	2891	3076	6821	7196	6868	6345	0	0
Point Tupper	Capacity Factor (%)	34	31	37	67	62	61	61	62	50	51
	Unit Cycles (Ranges)	10 - 25	< 10	10 - 25	< 10	10 - 25	10 - 25	10 - 25	10 - 25	25 - 50	25 - 50
	Service Hours	4464	3770	4647	7524	7033	7215	7060	7317	5510	5706
Trenton 5	Capacity Factor (%)	1	0	0	0	0	0	0	0	0	0
	Unit Cycles (Ranges)	< 10	0	0	0	0	0	0	0	0	0
	Service Hours	100	0	0	0	0	0	0	0	0	0
Trenton 6	Capacity Factor (%)	43	45	46	60	60	58	58	57	37	35
	Unit Cycles (Ranges)	< 10	< 10	< 10	< 10	10 - 25	10 - 25	10 - 25	10 - 25	10 - 25	10 - 25
	Service Hours	5739	6078	5862	6781	6788	6625	6705	6458	3720	3633
Tufts Cove 1	Capacity Factor (%)	19	15	13	7	0	0	0	0	0	0
	Unit Cycles (Ranges)	10 - 25	< 10	< 10	10 - 25	0	0	0	0	0	0
	Service Hours	2526	1870	1613	892	0	0	0	0	0	0
Tufts Cove 2	Capacity Factor (%)	10	9	11	9	0	0	0	0	0	0
	Unit Cycles (Ranges)	25 - 50	25 - 50	25 - 50	10 - 25	0	0	0	0	0	0
	Service Hours	1781	1413	1781	1599	0	0	0	0	0	0
Tufts Cove 3	Capacity Factor (%)	19	21	28	22	26	22	22	21	19	16
	Unit Cycles (Ranges)	25 - 50	25 - 50	25 - 50	10 - 25	50 - 100	25 - 50	25 - 50	25 - 50	25 - 50	25 - 50
	Service Hours	3415	3217	4435	4194	4643	3955	4009	3880	2804	2493
Tufts Cove 4	Capacity Factor (%)	69	73	67	66	68	68	66	69	67	68
	Unit Cycles (Ranges)	50 - 100	50 - 100	50 - 100	> 100	> 100	> 100	> 100	> 100	> 100	> 100
	Service Hours	6872	7220	6657	6377	6464	6518	6403	6819	6356	6429
Tufts Cove 5	Capacity Factor (%)	66	72	73	69	64	65	65	65	67	67
	Unit Cycles (Ranges)	50 - 100	50 - 100	50 - 100	> 100	> 100	> 100	> 100	> 100	> 100	> 100
	Service Hours	6622	7126	7316	6730	6114	6205	6281	6412	6357	6317
Tufts Cove 6	Capacity Factor (%)	39	42	38	41	44	44	44	43	45	45
	Unit Cycles (Ranges)	25 - 50	10 - 25	10 - 25	10 - 25	25 - 50	25 - 50	10 - 25	25 - 50	50 - 100	50 - 100
	Service Hours	7623	7753	6928	7595	7359	7209	7496	7265	7140	7048

1           **3.3.3 Steam Fleet Retirement Outlook**

2  
3           As part of the 2020 IRP, NS Power developed updated retirement scenarios and  
4           updated its forecast of major investment intervals for those units. The recent federal  
5           and provincial policy announcements to lower GHG emissions discussed in Section  
6           6.3 may affect steam unit retirement schedules. Legislative changes reflecting these  
7           policy announcements, when passed, will be reflected in future studies.

8  
9           **Figure 6** in Section 3.2.1 above provides the retirement schedule from Scenario  
10          2.0C, the Reference Plan from the 2020 IRP. Lingan Unit 2 is planned for  
11          retirement following the commencement of the delivery of the Nova Scotia Block  
12          of energy and related firm capacity from the Muskrat Falls and is assumed to be  
13          retired in Scenario 2.0C.

14  
15          Unit utilization and reliability objectives have long been the drivers for generator  
16          investment planning. Traditionally, in a predominantly base-loaded generation  
17          fleet, it was sufficient to consider capacity factor as the source for utilization  
18          forecasts for any given unit. This is no longer the case; integration of variable  
19          renewable resources on the NS Power system has imposed revised operating and  
20          flexibility demands to integrate wind generation on previously base-loaded steam  
21          units. Therefore, it is also necessary to consider the effects of unit starts, operating  
22          hours, flexible operating modes (e.g. ramping and two-shifting) and the latest  
23          understanding of asset health along with the forecast unit capacity factors.

24  
25          NS Power created the concept of utilization factor (UF) for the purpose of providing  
26          a directional understanding of the future use of each generating unit. This approach  
27          enables the Company to better demonstrate the demands placed upon NS Power's  
28          generating units given the planned utilization. The UF for each unit is evaluated  
29          by considering the forecast capacity factor, annual operating hours, unit starts,  
30          expected two-shifting, and a qualitative evaluation of asset health. By accounting

1 for these operational capabilities, the value brought to the power system by these  
2 units is more clearly reflected. Refer to **Figure 10** below.

3  
4 **Figure 10: Utilization Factor**  
5

$$U_{\text{Factor}}^{\text{Utilization}} = \text{fn} \left\{ \begin{array}{l} \text{Capacity} \\ \text{Factor} \end{array} \right. \left. \begin{array}{l} \text{Service} \\ \text{Hours} \end{array} \right. \left. \begin{array}{l} \text{Cycles} \end{array} \right. \left. \begin{array}{l} \text{Asset} \\ \text{Health} \end{array} \right\}$$

6  
7 The UF parameters are assessed to more completely describe the operational  
8 outlook for the steam fleet and direct investment planning. The four parameters are  
9 described below.

- 10
- 11 • Capacity factor reflects the energy production contribution of a generating  
12 unit and is a necessary constituent of unit utilization. It is a part of the  
13 utilization factor determination rather than the only consideration, as it  
14 would have been in the past.
  - 15
  - 16 • Service hours have become a more important factor to consider with  
17 increased penetration of variable-intermittent generation, as units are  
18 frequently running below their full capacity while providing load following  
19 and other essential reliability services for wind integration. For example, if  
20 a unit operates at 50 percent of its capacity for every hour of the year, then  
21 the capacity factor would be 50 percent. In a traditional model, this would  
22 suggest a reduced level of investment required, commensurate with  
23 decreased capacity factor. However, many failure mechanisms are a  
24 function of operating hours (e.g. turbines, some boiler failure mechanisms,  
25 and high energy piping) and the number of service hours (which in this  
26 example is every hour of the year) is not reflected by the unit's capacity



**2021 10-Year System Outlook**  
**NON-CONFIDENTIAL**

---

1 factor. Additionally, some failure mechanisms can actually be exacerbated  
2 by reducing load operation (e.g. valves, some pumps, throttling devices).

- 3 • Unit cycles (downward and upward ramping of generating units) can stress  
4 many components (e.g. turbines, motors, breakers, and fatigue in high  
5 energy piping systems) and accelerate failure mechanisms; therefore, these  
6 must also be considered to properly estimate the service interval and  
7 appropriate maintenance strategies.

- 8  
9 • Asset health is a critical operating parameter to keep at the forefront of all  
10 asset management decisions. For example, asset health may determine if a  
11 unit is capable of two-shifting (unit is shut down during low load overnight  
12 and restarts to serve load the next day). Although it does not necessarily  
13 play directly into the UF function, it can be a dominant determinant in  
14 allowing a mode of operation; therefore, it influences the UF function.

15  
16 While the UF rating provides a directional understanding of the future use of each  
17 generating unit, the practice of applying it has another layer of sophistication as  
18 system parameters change. NS Power utilizes the PLEXOS dispatch optimization  
19 model to derive utilization forecasts and qualitatively assess the UF of each unit by  
20 evaluating the components described above.

21  
22 **Figure 11** below provides the projected sustaining investments based on the  
23 anticipated utilization forecast in Section 3.3.2. Estimates of unit sustaining  
24 investment are forecast by applying the UF, related life consumption and known  
25 failure mechanisms. NS Power does not include unplanned failures in sustaining  
26 capital estimates. These estimates are evaluated at the asset class level; some asset  
27 class projections are prorated by the UF and others have additional overriding  
28 factors. For example, the use of many instrument and electrical systems is a  
29 function of calendar years, as they operate whether a unit is running or not.  
30 Investments for coal and ash systems are a direct function of capacity factor, as they

**2021 10-Year System Outlook**  
**NON-CONFIDENTIAL**

---

1 typically have material volume-based failure mechanisms. In contrast, the UF is  
2 directly applicable to the investment associated with turbines, boilers and high  
3 energy piping. Major assets are regularly re-assessed in terms of their condition  
4 and intended service as NS Power’s operational data, utilization plan, asset health  
5 information, and forecasts are updated.

6  
7 **Figure 11: Forecast Unit Utilization Factors**

8

<b>Unit</b>	<b>UF(2022-2026)</b>	<b>UF(2027-2031)</b>
LIN-1	Medium	Medium
LIN-2	Off	Off
LIN-3	Medium	Medium
LIN-4	Medium	Medium
PHB-1	High	High
POA-1	Medium	High
POT-2	Medium	High
TRE-5	Low/Off	Off
TRE-6	High	High
TUC-1	Low	Off
TUC-2	Medium	Off
TUC-3	Medium	Medium
TUC-4	High	High
TUC-5	High	High
TUC-6	High	High


9  
10 The overarching investment philosophy is to cost effectively maintain unit  
11 reliability while minimizing undepreciated capital. Mitigating risks by using less  
12 intensive investment strategies is a method executed throughout the thermal fleet.

**2021 10-Year System Outlook  
NON-CONFIDENTIAL**

1 Major outage intervals are extended where possible to reduce large investments in  
2 the thermal fleet.

3  
4 The total sustaining capital forecasts in **Figure 12** are generally under the 2020 IRP  
5 sustaining capital assumptions since the utilization factors are updated with model  
6 output data versus being conservatively modeled at a high utilization factor in the  
7 2020 IRP process.  
8

9 **Figure 12: Forecast Annual Investment (in 2021\$) by Unit**



11  
12 Note: Figure does not include escalation as it is used for asset planning. Forecast investments are subject to change  
13 arising from asset health and actual utilization. Changes in currency value can also have significant effect on actual  
14 cost.

1   **4.0   NEW SUPPLY SIDE FACILITIES**

2  
3   As of June 18, 2021 NS Power has 21 active Transmission Connected Interconnection Requests  
4   (1408.8 MW) and 15 active Distribution Connected Interconnection Requests (92.45 MW) at  
5   various stages of interconnection study. The Advanced Stage Interconnection Request Queue is  
6   described in Section 5.

7  
8   Proponents of transmission projects request Network Resource Interconnection Service (NRIS) or  
9   Energy Resource Interconnection Service (ERIS). NRIS refers to a firm transmission  
10   interconnection request with the potential requirement for transmission reinforcement upon  
11   completion of the System Impact Study (SIS). ERIS refers to an interconnection request for firm  
12   service only to the point where transmission reinforcement would be required. Results of the  
13   transmission interconnection studies assessing the transmission reinforcement required to support  
14   transmission projects will be incorporated into future transmission plans.

15  
16   Distribution projects do not receive a NRIS or ERIS designation.

**2021 10-Year System Outlook  
NON-CONFIDENTIAL**

1 **5.0 QUEUED SYSTEM IMPACT STUDIES**

2  
3 **Figure 13** below provides the current combined Transmission and Distribution Advanced State  
4 Interconnection Queue.

5  
6 **Figure 13: Combined Transmission & Distribution Advanced Stage Interconnection**  
7 **Queue as of June 18, 2021**

8

Queue Order	IR#	Request Date DD-MMM-YY	County	MW Summer	MW Winter	Inter-connection Point	Type	In-Service date DD-MMM-YY <sup>24</sup>	Status	Service Type
1-T	426	27-Jul-12	Richmond	45.0	45.0	47C	Biomass	01-Sep-18	GIA Executed	NRIS
2-T	516	5-Dec-14	Cumberland	5.0	5.0	37N	Tidal	31-May-20	GIA Executed	NRIS
3-T	540	28-Jul-16	Hants	14.1	14.1	17V	Wind	31-Oct-23	GIA Executed	NRIS
4-T	542	26-Sep-16	Cumberland	3.78	3.78	37N	Tidal	01-Nov-21	GIA Executed	NRIS
5-D	557	19-Apr-17	Halifax	5.6	5.6	24H	CHP	01-Sep-18	SIS Complete	N/A
6-D	569	26-Jul-19	Digby	0.6	0.6	509V-302	Tidal	30-Jul-21	GIA Executed	N/A
7-D	568	21-May-19	Cumberland	2.0	2.0	22N-404	Solar	01-Sep-21	GIA Executed	N/A
8-D	566	16-Jan-19	Digby	0.7	0.7	509V-301	Tidal	29-Jan-21	GIA Executed	N/A
9-T	574	27-Aug-20	Hants	58.8	58.8	L-6051	Wind	30-Jun-23	FAC in Progress	NRIS
10-D	595	11-Mar-21	Halifax	0.1	0.1	1H-454	Battery	11-Jan-21	SIS in Progress	N/A
11-T	598	13-May-21	Cumberland	2.52	2.52	37N	Tidal	01-Dec-22	SIS Milestones Met	NRIS

9  
10 Active transmission and distribution requests not appearing in the Combined Transmission &  
11 Distribution Advanced Stage Interconnection Request Queue are considered to be at the initial  
12 queue stage, as they have not yet proceeded to the SIS stage of the Generator Interconnection

<sup>24</sup> The In-Service dates listed reflect the milestone dates specified in the interconnection agreement with the Interconnection Customer associated with each individual Interconnection Request or as last specified by the Interconnection Customer in interconnection study related agreements.

**2021 10-Year System Outlook  
NON-CONFIDENTIAL**

---

1 Procedures (GIP) or Distribution Generator Interconnection Procedures (DGIP). **Figure 13** above  
2 provides the location and size of the generating facilities currently in the Combined T&D  
3 Advanced Stage Interconnection Request Queue.

4  
5 The Port Hawkesbury Biomass generating unit (63.8 MW gross / 45 MW net output) is presently  
6 an ERIS classified resource which will be converted to NRIS following the system upgrades  
7 associated with Transmission Service Request 400 which is discussed further in Section 5.1.

8  
9 **5.1 OATT Transmission Service Queue**

10  
11 As of June 15, 2021 as shown in **Figure 14**, there are four ongoing requests in the OATT  
12 Transmission Queue.

13  
14 **Figure 14: Requests in the OATT Transmission Queue**

15

Item	Project	Date & Time of Service Request	Project Type	Project Location	Requested In Service Date	Project Size (MW)	Status
1	TSR 400	July 22, 2011	Point-to-point	NS-NB*	May 2019	330	System Upgrades in Progress
2	TSR 411	January 19, 2021	Point-to-point	NS-NB*	January 1, 2025	800	SIS in Progress
3	TSR 412	January 19, 2021	Point-to-point	Woodbine - NS	January 1, 2025	500	SIS in Progress
4	TSR 413	April 14, 2021	Network	Antigonish - NS	January 1, 2022	8.792	Application Accepted

16 \*Indicates project as being located near provincial border.

**2021 10-Year System Outlook**  
**NON-CONFIDENTIAL**

---

1 In its Decision on the 2020 10-Year System Outlook, the UARB provided the following  
2 direction with respect to the information provided about Requests in the OATT  
3 Transmission Queue:<sup>25</sup>  
4

5 In section 5.1 of the SO Report, Figure 8 lists the requests that are currently  
6 in the OATT transmission queue. Some of those requests are for network  
7 service while others are for point-to-point service. The Board directs that  
8 future reports include an expanded description in the column titled “Project  
9 Location” for each request.

10  
11 Information in **Figure 14** under Project Location reflects the non-confidential  
12 information provided in the customer’s application. Details regarding the location of  
13 the generating facility(ies) supplying the capacity and energy and the location of the  
14 load ultimately served by the capacity and energy transmitted are deemed confidential  
15 under Section 17.2 of the OATT<sup>26</sup> and not available to the public on the Open Access  
16 Same-Time Information System (OASIS). As such there is limited further information the  
17 Company can include in this Report on a non-confidential basis. However, in an effort  
18 to be responsive to the NSUARB’s direction and maintain the non-confidential nature  
19 of the Report, NS Power has provided additional information in the note to **Figure 14**.

20  
21 System upgrades related to Transmission Service Request 400 now have their design  
22 complete. Execution of upgrades is pending the procurement of materials and is planned  
23 for Q4 2021.  
24

25 Studies are being performed to determine the system upgrades necessary for TSR 411 and  
26 TSR 412.

---

<sup>25</sup> M09776, Nova Scotia Power 2020 10-Year System Outlook Report (P-194), NSUARB Letter re accepted as filed, August 28, 2020.

<sup>26</sup> Nova Scotia Power Inc. Open Access Transmission Tariff As approved by the UARB May 31, 2005 and As Amended June 10, 2016. The OATT is available on NS Power’s website at [https://www.nspower.ca/docs/default-source/pdf-to-upload/revise-oatt-june-10-2016.pdf?sfvrsn=7d69fd73\\_0](https://www.nspower.ca/docs/default-source/pdf-to-upload/revise-oatt-june-10-2016.pdf?sfvrsn=7d69fd73_0)

1   **6.0   ENVIRONMENTAL AND EMISSIONS REGULATORY REQUIREMENTS**

2  
3   **6.1   Renewable Electricity Requirements**

4  
5       The Nova Scotia *Renewable Electricity Standards* (RES) include a renewable energy  
6       requirement for NS Power of 25 percent of energy sales in 2015, and 40 percent in 2020.<sup>27</sup>

7       As discussed below in Section 6.3, in February 2021, the Government of Nova Scotia also  
8       announced its intention to implement a RES of 80 percent by 2030. As of the time of  
9       preparing this study, an updated 2030 RES requirement has not yet been reflected in  
10      regulations.

11  
12      In addition, Nova Scotia has a Community Feed-in-Tariff (COMFIT) for projects which  
13      include community ownership that are connected to the distribution system and Net  
14      Metering legislation for renewable projects.<sup>28</sup> The current Net Metering program was  
15      initiated in July 2011, and implementation of the COMFIT program occurred in September  
16      2011.

17  
18      On April 8, 2016 the Province amended the *Renewable Electricity Regulations* to allow  
19      NS Power to include COMFIT projects in its RES compliance planning. It also amended  
20      the Regulations to remove the “must-run” requirement of the Port Hawkesbury biomass  
21      generating facility.<sup>29</sup>

---

<sup>27</sup> *Renewable Electricity Regulations*, made under Section 5 of the *Electricity Act* S.N.S. 2004, c. 25 O.I.C. 2010-381 (effective October 12, 2010), N.S. Reg. 155/2010 as amended to O.I.C. 2020-147 (effective May 5, 2020), N.S. Reg. 74/2020 s. 5(2A).

<sup>28</sup> Effective December 18, 2015, the *Electricity Act* reduced the maximum nameplate capacity for Net Metering from 1,000 kW to 100 kW. Net metering applications submitted on or after December 18, 2015 are subject to the new 100 kW limit. The legislation also closed the COMFIT to new applications.

<sup>29</sup> *Renewable Electricity Regulations*, made under Section 5 of the *Electricity Act* S.N.S. 2004, c. 25 O.I.C. 2010-381 (effective October 12, 2010), N.S. Reg. 155/2010 as amended to O.I.C. 2020-147 (effective May 5, 2020), N.S. Reg. 74/2020 s. 5(2A).



**2021 10-Year System Outlook**  
**NON-CONFIDENTIAL**

---

1 NS Power has complied with or exceeded the renewable electricity requirement in all  
2 applicable years. From 2015 to 2020 the Company served 26.6 percent (2015), 28 percent  
3 (2016), 29 percent (2017), 30 percent (2018), 30 percent (2019) and 29 percent of sales  
4 (2020) using qualifying renewable energy sources.

5  
6 A key component of NS Power’s ability to meet its 2020 RES requirements was the  
7 commencement of the operation the Muskrat Falls Hydro Generating Project and the  
8 associated delivery of renewable energy. On March 27, 2020 Nalcor Energy (Nalcor)  
9 announced that it temporarily paused construction activities at the Muskrat Falls project  
10 site in response to the COVID-19 pandemic.<sup>30</sup> Construction and commissioning of the  
11 Muskrat Falls hydro project subsequently resumed on May 30, 2020. Given the risk of a  
12 delay in the delivery of the Nova Scotia Block, the Nova Scotia Minister of Energy and  
13 Mines permitted NS Power to address this through an Alternative Compliance Plan for  
14 2020 through 2022 under the RES Regulations. The Minister’s Alternative Compliance  
15 Plan, in part, directs NS Power to make up the shortfall extending the compliance period  
16 for meeting the 40 percent renewable energy standard over the three calendar years 2020,  
17 2021, and 2022. The Company is on track to meet its RES compliance requirements for  
18 the 2020 through 2022 period.

19  
20 On May 6, 2021 Newfoundland and Labrador Hydro wrote to the Newfoundland and  
21 Labrador Board of Commissioners of Public Utilities, stating, “Based on the schedules  
22 presented above, the overall Muskrat Falls Project completion date is currently November  
23 14, 2021.”

24  
25 The RES Compliance Forecast in **Figure 15** illustrates the full amount of RES-eligible  
26 energy forecast to be available to the Company if the Nova Scotia Block energy flow begins  
27 on December 1, 2021.

---

<sup>30</sup> <https://muskratfalls.nalcorenergy.com/march-27-2020-covid-19-update-from-nalcor-on-the-muskrat-falls-project/>

---

**2021 10-Year System Outlook  
NON-CONFIDENTIAL**

**Figure 15: RES Compliance Forecast**

<b>RES Compliance Forecast<sup>31</sup></b>			
	<b>2022</b>	<b>2023</b>	<b>2024</b>
<b>Energy Requirements (GWh)</b>			
NSR including DSM effects	11,005	11,043	11,119
Losses	684	687	692
Sales	10,321	10,356	10,427
RES (%) Requirement	40%	40%	40%
<b>RES Requirement (GWh)</b>	<b>4,128</b>	<b>4,142</b>	<b>4,171</b>
<b>Renewable Energy Sources (GWh)</b>			
NS Power Wind	264	264	264
Post-2001 IPPs	770	770	770
PH Biomass	290	290	290
COMFIT Wind Energy	523	523	523
COMFIT Non-Wind Energy	15	15	15
Eligible Pre-2001 IPPs	80	82	77
Eligible NSPI Legacy Hydro	894	885	896
REA procurement (South Canoe/Sable)	357	357	357
Compliant Renewable Import	1,134	1,134	1,134
<b>Forecast Renewable Energy (GWh)</b>	<b>4,328</b>	<b>4,320</b>	<b>4,327</b>
<b>Forecast Surplus or Deficit (GWh)</b>	<b>199</b>	<b>178</b>	<b>156</b>
<b>Forecast RES Percentage of Sales</b>	<b>42%</b>	<b>42%</b>	<b>41%</b>

\*This assumes the full year of Maritime Link energy flow.

<sup>31</sup> NSR and Losses are provided in the 2021 NS Power Load Forecast Report, Table A-1, April 30, 2021 (M10109).

1   **6.2   Environmental Regulatory Requirements**

2  
3       The Nova Scotia *Greenhouse Gas Emissions Regulations*<sup>32</sup> specify emission caps for 2010-  
4       2030, as outlined in **Figure 16**. The net result is a hard cap reduction from 10.0 to 4.5  
5       million tonnes over that 20-year period, which represents a 55 percent reduction in CO<sub>2</sub>  
6       release over 20 years. Carbon emissions in Nova Scotia from the production of electricity  
7       in 2030 are forecast to have decreased by 58 percent from 2005 levels.

8  
9       **Figure 16: Multi-year Greenhouse Gas Emission Limits**

10

<b>Year</b>	<b>GHG Cumulative Million tonnes</b>
2014-2016	26.32
2017-2019	24.06
2020	7.5 (annual)
2021-2024	27.5
2025	6 (annual)
2026-2029	21.5
2030	4.5 (annual)

11  
12       The *Sustainable Development Goals Act*<sup>33</sup> states Nova Scotia’s goals to achieve province-  
13       wide greenhouse gas emission reductions of at least 10 percent below levels emitted in  
14       1990 by 2020, at least 33 percent below the levels that were emitted in 2005 by 2030, and

---

<sup>32</sup> *Greenhouse Gas Emissions Regulations* made under subsection 28(6) and Section 112 of the Environment Act S.N.S. 1994-95, c. 1, O.I.C. 2009-341 (August 14, 2009), N.S. Reg. 260/2009 as amended to O.I.C. 2013-332 (September 10, 2013), N.S. Reg. 305/2013.

<sup>33</sup> *An Act to Achieve Environmental Goals and Sustainable Prosperity*, S.N.S. 2019, c. 26, not proclaimed in force.

**2021 10-Year System Outlook**  
**NON-CONFIDENTIAL**

---

1 a “net zero” by 2050 by balancing greenhouse gas emissions with greenhouse gas removals  
2 and other offsetting measures.

3 On January 1, 2019 Nova Scotia’s cap-and-trade program came into effect. The *Cap-and-*  
4 *Trade Program Regulations* include the annual free allowances for GHG emissions for NS  
5 Power.

6  
7 Under the GHG cap-and-trade system NS Power is allowed to purchase no more than 5  
8 percent of GHG credits which may be offered for auction by the province. Nova Scotia  
9 Power is forecasting that the GHG credits available for the company to purchase will be  
10 approximately 0.05 Mt annually. Although bilateral GHG trades among participants are  
11 permitted, there have been no bilateral trades reported to date and any liquidity in this  
12 market is likely to be slow to develop. Due to limited GHG credit purchase opportunities,  
13 the primary means of meeting the caps is a reduction in thermal generation from the  
14 existing coal-fired generating units, replaced by low-emitting energy.

15  
16 Although the free GHG allowance under the GHG cap-and-trade system was specified for  
17 each year from 2019 to 2022 as noted in **Figure 17**, the allowances can be redistributed in  
18 a four-year compliance period between 2019 and 2022 in order to reduce the cost of  
19 compliance. NS Power is on track to meet the requirements of the program, where  
20 compliance is forecast to be achieved through reduced emissions and credit purchases.

21  
22 **Figure 17: Greenhouse Gas Free Allowances 2019-2022**

<b>Year</b>	<b>GHG Free Allowances Million tonnes</b>
2019	6.334
2020	5.517
2021	5.120
2022	5.087

**2021 10-Year System Outlook**  
**NON-CONFIDENTIAL**

---

1 NS Power thermal facilities that meet the CO<sub>2</sub> emissions threshold for cap-and-trade  
2 (50,000 tonnes) are not required to pay fuel surcharges on fuel consumed for electricity  
3 generation. Fuel consumed for on-site activities via mobile equipment is subject to a fuel  
4 surcharge under the *Cap-and-Trade Regulations*.

5  
6 As the Port Hawkesbury Biomass facility and the combustion turbine sites do not meet the  
7 emissions threshold, fuel consumed on those sites will be subject to fuel surcharges under  
8 the *Cap and Trade Regulations*.

9  
10 The Nova Scotia *Air Quality Regulations*<sup>34</sup> specify emission caps for sulphur dioxide  
11 (SO<sub>2</sub>), nitrogen oxides (NO<sub>x</sub>), and mercury (Hg). These regulations were amended to  
12 extend from 2020 to 2030, effective January 1, 2015. The amended regulations replaced  
13 annual limits with multi-year caps for the emissions targets for SO<sub>2</sub> and NO<sub>x</sub>.

14  
15 The Province introduced amendments to the *Air Quality Regulations* respecting the SO<sub>2</sub>  
16 cap for a three-year period from 2020 to 2022, effective January 21, 2020. The regulations  
17 also provide local annual maximums, as well as limits on individual coal units for SO<sub>2</sub>.  
18 The revised emissions requirements are shown below in **Figure 18**.

---

<sup>34</sup> *Air Quality Regulations* made under Sections 25 and 112 of the Environment Act S.N.S. 1994-95, c. 1 O.I.C. 2005-87 (February 25, 2005, effective March 1, 2005), N.S. Reg. 28/2005 as amended to O.I.C. 2020-016 (effective January 21, 2020), N.S. Reg. 8/2020.

**2021 10-Year System Outlook  
NON-CONFIDENTIAL**

**Figure 18: Emissions (SO<sub>2</sub>, NO<sub>x</sub>, Hg)**

<b>Multi-Year Caps Period</b>	<b>SO<sub>2</sub> (t)</b>	<b>SO<sub>2</sub> (t) Annual Max</b>	<b>NO<sub>x</sub> (t)</b>	<b>NO<sub>x</sub> (t) Annual Max</b>	<b>Hg (kg)</b>
2020	60,900				35
2021-2022	90,000		14,955	14,955	35
2023-2024	68,000		56,000		35
2025	28,000		11,500		35
2026 – 2029	104,000	28,000	44,000	11,500	35
2030	20,000		8,800		30

By 2030, SO<sub>2</sub> emissions from generating electricity will have been reduced by 80 percent from 2005 levels. NO<sub>x</sub> emissions will have decreased by 73 percent and mercury emissions will have decreased 71 percent from 2005 levels.

SO<sub>2</sub> reductions are being addressed mainly by reduced thermal generation and changes to fuel blends. NO<sub>x</sub> reductions are being addressed through reductions in thermal generation and the previous installation of Low NO<sub>x</sub> Combustion Firing Systems. Mercury reductions are being accomplished through reduced thermal generation, changed fuel blends and the use of Powder Activated Carbon systems. NS Power offered a mercury recovery program, such as recycling light bulbs or other mercury-containing consumer products, which reduced the amount of mercury going into the environment through landfills. The amount of mercury diverted in 2019 resulted in the total amount of credits exceeding the credit target for the program; therefore, NS Power no longer funded the program as of January 31, 2020. Credits approved by Nova Scotia Environment and Climate Change (ECC) may be used to compensate from the deferred emissions by 2020, and a limited amount of credits approved by ECC (30 kg in 2020, 10 kg per year for subsequent years) may be used for compliance from 2020 to 2029.

1   **6.3   Anticipated Policy Changes**

2  
3       Until the federal coal phase-out policy changes announced in the fall of 2016,<sup>35</sup> NS Power’s  
4       operation of and planning for its coal-fired generation units proceeded consistent with the  
5       provisions of the Agreement on Equivalency of Federal and Nova Scotia Regulations for  
6       the Control of Greenhouse Gas Emissions from Electricity Producers in Nova Scotia (the  
7       Equivalency Agreement). The Equivalency Agreement was finalized in May 2014 and  
8       commenced in July 2015, contemporaneous with the effective date for the current federal  
9       *Reduction of Carbon Dioxide Emissions from Coal-Fired Generation of Electricity*  
10      *Regulations*.

11  
12      In November 2016, the Province of Nova Scotia announced that an agreement-in-principle  
13      had been reached with the Government of Canada to develop a new equivalency agreement  
14      driven by amendments proposed by the Federal Government to the *Reduction of Carbon*  
15      *Dioxide Emissions from Coal-fired Generation of Electricity Regulations*.<sup>36</sup> On March 30,  
16      2019 the Renewal of this Equivalency Agreement was published in Canada Gazette I. This  
17      Equivalency is valid until 2024, with notional direction to 2029.

18  
19      The Federal Government recently announced its intention to cease all coal-fired electricity  
20      generation by 2030. The Government of Nova Scotia has indicated a similar intention  
21      with respect to the Province of Nova Scotia. In February 2021 the Government of Nova  
22      Scotia announced its intention to implement a Renewable Energy Standard of 80 percent  
23      by 2030. In addition, the Federal Government has also indicated its intention to increase  
24      the cost of GHG emissions by increasing the Federal carbon price by \$15/tonne beginning  
25      in 2023 and reaching a level of \$170/tonne by 2030.

---

<sup>35</sup> [https://www.canada.ca/en/environment-climate-change/news/2017/11/taking\\_action\\_tophase-outcoalpower.html](https://www.canada.ca/en/environment-climate-change/news/2017/11/taking_action_tophase-outcoalpower.html)

<sup>36</sup> Vol. 152, No. 7 Canada Gazette Part I Ottawa, Saturday, February 17, 2018.

**2021 10-Year System Outlook**  
**NON-CONFIDENTIAL**

---

1           In response to these recent governmental policy statements and to better prepare for the  
2           potential that these policy statements become law, NS Power is developing a  
3           comprehensive plan to transform its generation fleet, eliminating coal-fired generation by  
4           2030 and reducing GHG emissions to 1-2 Mt/year by 2030. NS Power continues to engage  
5           with both levels of government to explore opportunities to accelerate the Company's  
6           carbon reduction strategy in a way that is affordable for customers and that supports NS  
7           Power's customers and the communities where they live and work.

8  
9           As the government's announced policy changes become legislative and regulatory  
10          requirements, NS Power will reflect these changes in future planning studies.



1   **7.0   RESOURCE ADEQUACY**

2  
3   **7.1   Operating Reserve Criteria**

4  
5       Operating Reserves are resources which can be called upon by system operators on short  
6       notice to respond to the unplanned loss of generation or imports. These assets are essential  
7       to the reliability of the power system.

8  
9       As a member of the Maritimes Area of NPCC, NS Power meets the operating reserve  
10       requirements as outlined in *NPCC Regional Reliability Reference Directory #5, Reserve*.  
11       These Criteria are reviewed and adjusted periodically by NPCC and subject to approval by  
12       the NSUARB. The Criteria require that:

13  
14               Each Balancing Authority shall have ten-minute reserve available that is at  
15               least equal to its first contingency loss...and,

16  
17               Each Balancing Authority shall have thirty-minute reserve available that is  
18               at least equal to one half its second contingency loss.<sup>37</sup>

19  
20       In the *Interconnection Agreement between Nova Scotia Power Incorporated and New*  
21       *Brunswick System Operator (NBSO)*<sup>38</sup> NS Power and New Brunswick Power (NB Power)  
22       have agreed to share the reserve requirement for the Maritimes Area on the following basis:

23  
24               The Ten-Minute Reserve Responsibility, for contingencies within the  
25               Maritimes Area, will be shared between the two Parties based on a 12CP  
26               [coincident peak] Load-Ratio Share... Notwithstanding the Load-Ratio  
27               Share the maximum that either Party will be responsible for is 100 percent  
28               of its greatest, on-line, net single contingency, and, NSPI shall be  
29               responsible for 50 MW of Thirty-Minute Reserve.

---

37 <https://www.npcc.org/program-areas/standards-and-criteria/regional-criteria/directories>

38 New Brunswick's Electricity Act (the Act) was proclaimed on October 1, 2013. Among other things, the Act establishes the amalgamation of the New Brunswick System Operator (NBSO) with New Brunswick Power Corporation ("NB Power").

1 The Ten-Minute Reserve Responsibility formula results in a reserve share of approximately  
2 40 percent of the largest loss-of-source contingency in the Maritimes Area (limited to 10  
3 percent of Maritimes Area coincident peak load). This yields a reserve share requirement  
4 for NS Power of approximately 40 percent of 550 MW, or 220 MW, capped at the largest  
5 on-line unit in Nova Scotia. When Point Aconi is online, NS Power maintains a ten-minute  
6 operating reserve of 168 MW (equivalent to Point Aconi net output), of which  
7 approximately 33 MW is held as spinning reserve on the system. Additional regulating  
8 reserve is maintained to manage the variability of customer load and generation. The  
9 reserve sharing requirement with Maritime Link as the largest source in Nova Scotia will  
10 depend on the amount of Maritime Link power used in Nova Scotia.

## 11

### 12 **7.2 Planning Reserve Criteria**

13  
14 The Planning Reserve Margin (PRM) is intended to maintain sufficient resources to  
15 reliably serve firm customers. Unit forced outages, higher than forecast demand, and lower  
16 than forecast wind generation are all conditions that could individually or collectively  
17 contribute to a shortfall of dispatchable capacity resources to meet customer demand.

18  
19 NS Power is required to comply with the NPCC reliability criteria that have been approved  
20 by the NSUARB. These criteria are outlined in *NPCC Regional Reliability Reference*  
21 *Directory #1 – Design and Operation of the Bulk Power System*<sup>39</sup> which states:

22  
23 Each Planning Coordinator or Resource Planner shall probabilistically  
24 evaluate resource adequacy of its Planning Coordinator Area portion of the  
25 bulk power system to demonstrate that the loss of load expectation (LOLE)  
26 of disconnecting firm load due to resource deficiencies is, on average, no  
27 more than 0.1 days per year. [This evaluation shall] make due allowances  
28 for demand uncertainty, scheduled outages and deratings, forced outages  
29 and deratings, assistance over interconnections with neighboring Planning  
30 Coordinator Areas, transmission transfer capabilities, and capacity and/or  
31 load relief from available operating procedures.

---

<sup>39</sup> <https://www.npcc.org/program-areas/standards-and-criteria/regional-criteria/directories>

**2021 10-Year System Outlook**  
**NON-CONFIDENTIAL**

---

1 The PRM is a long-term planning assumption that is typically updated as part of an IRP  
2 process. In advance of the 2020 IRP, NS Power engaged Energy+Environmental  
3 Economics Consulting, LLC (E3) to undertake a PRM and capacity value study. The study  
4 found that in order to meet a 0.1 days/year loss of load expectation (LOLE) target and  
5 comply with the NPCC reliability requirements, NS Power should maintain a PRM  
6 between 17.8 percent and 21 percent.<sup>40</sup> The range in target PRM is due to a higher and  
7 lower estimate of operating reserve requirements for the NS Power system. NS Power  
8 studied the appropriate calculation of its PRM as part of the 2020 IRP.<sup>41</sup> The 2020 IRP  
9 confirmed that this PRM target was appropriate for long term planning, as noted in the  
10 report:

11  
12 There are two alternative PRM accounting methods commonly used in the  
13 industry, based on using a unit's unforced capacity (UCAP) or installed  
14 capacity (ICAP) values. While either method will result in the same  
15 reliability standard and the same total quantity of effective capacity, the  
16 methods differ in how they measure qualifying capacity. ICAP accounting  
17 credits traditional dispatchable resources (e.g., coal, natural gas) at their  
18 nameplate capacity, without considering forced outage de-rates, and credits  
19 energy-limited resources, including solar, wind, hydro, and battery storage,  
20 at their effective load carrying capacity (discussed in further detail below).  
21 As an alternative, utilities and capacity markets are beginning to transition  
22 to an unforced capacity (UCAP) rather than installed capacity (ICAP)  
23 approach to determine the PRM for purposes specifically associated with  
24 capacity expansion modeling. This UCAP value adjusts the peak  
25 contribution of thermal resources to account for their forced outage or  
26 deratings, instead accounting for these resources based on their UCAP or  
27 unforced capacity value. This approach puts existing and candidate thermal  
28 and renewable resources on an "equal footing" by accounting for the  
29 resources' contributions to peak in a consistent way. For the 2020 IRP, Nova  
30 Scotia Power used its existing 20 percent ICAP PRM, which the E3 planning  
31 and reserve margin study verified was within the range of PRMs consistent  
32 with the reliability criterion, and converted this to an equivalent 9 percent  
33 UCAP PRM. This UCAP translated value was adopted for the capacity  
34 expansion modeling only, based on feedback and discussion with IRP

---

<sup>40</sup> M08929, Energy + Environmental Economics, Planning Reserve Margin and Capacity Value Study for Nova Scotia Power Inc. July 2019 found as Attachment 17 to NS Power's [Pre-IRP Deliverables Report](https://irp.nspower.ca/documents/pre-irp-deliverables/) located at <https://irp.nspower.ca/documents/pre-irp-deliverables/>.

<sup>41</sup>M08929, Nova Scotia Power, IRP Final Report, November 27, 2020, page 40.

**2021 10-Year System Outlook**  
**NON-CONFIDENTIAL**

---

1 participants, to ensure that renewable resources (primarily wind) would face  
2 an equivalent crediting formula to new and existing thermal alternatives.  
3 This choice does not change the reliability criterion or use of ICAP PRM  
4 calculations in other reporting and analysis. The PRM target will remain  
5 appropriate for as long as the given load characteristics and reserve  
6 requirements remain consistent. As Nova Scotia Power begins to serve new  
7 electrification load, or as significant changes start to occur to the overall  
8 generation mix, the appropriate PRM may require re-evaluation and  
9 adjustment.

10  
11 The PRM provides a basis for the minimum required firm generation NS Power must plan  
12 to maintain to comply with NPCC reliability criteria; it does not represent the optimal or  
13 maximum required capacity to serve other system requirements such as load following  
14 (ramping capability) and emissions compliance. The optimal capacity requirement is  
15 determined through a long-term planning exercise such as the 2020 IRP, as discussed in  
16 Section 7.4 below.

1   **7.3   Capacity Contribution of Renewable Resources in Nova Scotia**

2  
3       Due to their variability, renewable energy resources, such as wind and solar, are not always  
4       available to contribute during peak demand hours. The Effective Load Carrying Capability  
5       (ELCC), or “capacity value” of a resource represents the statistical likelihood that it will  
6       be available to serve the firm peak demand, and as a result, what percentage of its capacity  
7       can be counted on as firm for system planning. Loss of Load Expectation (LOLE) studies  
8       are the industry standard used to calculate the ELCC or capacity value of these renewable  
9       resources.

10  
11       By letter dated October 5, 2018<sup>42</sup> the NSUARB directed NS Power to complete a number  
12       of pre-IRP analyses by July 31, 2019. One of the pre-IRP deliverables directed by the  
13       NSUARB was a Capacity Study to calculate the ELCC of wind and other renewable energy  
14       generators, both for the existing wind resources as well as potential new resources. The  
15       study was undertaken by E3<sup>43</sup> on behalf of NS Power and the results determined the  
16       average ELCC of the wind currently installed on the NS Power system to be 19 percent.  
17       The declining marginal ELCC value of adding new wind to the NS Power system was  
18       determined to be 11 to 9 percent. In the 2020 IRP, the Company used 10 percent for the  
19       ELCC value of new wind. The ELCC value of Hydro was determined to be 95 percent. For  
20       the purposes of this Report, NS Power has used the 18 percent capacity value of existing  
21       wind to account for the wind farm serving wholesale market participants under the BUTU  
22       Tariff, 10 percent capacity value of new wind, and 95 percent for hydro.

23  
24       Please refer to Section 7.3.1 regarding the inclusion of ERIS wind resources.

---

<sup>42</sup> M08059, UARB Decision Letter, Generation Utilization and Optimization, October 5, 2018.

<sup>43</sup> M08929, Integrated Resource Planning and Generation Utilization and Optimization (P-884)  
Energy+Environmental Economics, Planning Reserve Margin and Capacity Value Study, July 2019, Attachment 18  
to NS Power’s Pre-IRP Final Report at <https://irp.nspower.ca/documents/pre-irp-deliverables/>

1           Municipal load for Berwick, Mahone Bay, Antigonish and Riverport is served by a wind  
2           farm owned by Alternative Resource Energy Authority (AREA) and by imports. This  
3           generation is not included in NS Power's sourced wind generation but contributes to  
4           operational considerations of the total amount of wind generation.

5  
6           **7.3.1 Energy Resource Interconnection Service Connected Resources**

7  
8           In the 2018, 10-Year System Outlook Report, NS Power provided a study to  
9           determine the potential capacity contribution of ERIS facilities based on current  
10          system configuration and conditions. The study concluded that existing ERIS  
11          facilities can operate as though they are NRIS facilities and therefore can contribute  
12          to system capacity for the purposes of resource planning at this time without the  
13          requirement for additional system upgrades. The transmission system upgrades  
14          undertaken to enable the transmission of Maritime Link energy across Nova Scotia  
15          contributed to the change to ERIS facility capacity treatment.

16  
17          Consistent with this, and for the purposes of reflecting this potential additional  
18          capacity in this Report, NS Power has applied a capacity value of 18 percent to  
19          existing wind resources, both ERIS and NRIS, in this Report. Please refer to Section  
20          7.3 for further information on the capacity study used to determine the 18 percent.

21  
22          This represents a new area for resource planning and remains subject to change.  
23          Until these matters are better understood it remains premature to make longer-term  
24          resource planning decisions based on this capacity addition. The Company will  
25          continue to monitor this resource planning input and will refine the capacity  
26          estimates as required. Changes, if necessary, will be incorporated within future 10-  
27          Year System Outlook Reports.

1   **7.4   Load and Resources Review**

2  
3       The 10-year load and resources outlook in **Figure 19** is based on the capacity changes and  
4       DSM forecast from **Figure 5**, and provides details regarding NS Power’s required  
5       minimum forecast PRM equal to 20 percent of the firm peak load.

6  
7       The current forecast indicates a capacity deficit from 2022 until 2024. Solutions for  
8       capacity shortfalls will be evaluated including access to firm capacity if required. NS  
9       Power will continue to monitor potential deficits or apparent surpluses as forecasts  
10      continue to evolve and will adjust decisions accordingly.

11  
12      **Figure 19** is intended to provide a medium-term outlook of the capacity resources available  
13      to the Company compared to expected customer demand, given the most recent  
14      assumptions to date. As noted in Section 7.2, the PRM provides a basis for the minimum  
15      required firm generation NS Power must maintain to comply with NPCC reliability criteria;  
16      it does not necessarily represent the optimal or maximum required capacity to serve other  
17      system requirements such as wind-following (ramping capability) and emissions  
18      compliance. In its Final Report submitted to the NSUARB in the Generation Utilization  
19      and Optimization proceeding,<sup>44</sup> Synapse stated:

20  
21           The PRMs provide one high-level measure of the amount of generation  
22           capacity relative to the NPCC 20 percent planning reserve margin  
23           requirement. PRM is defined as the amount of firm capacity available over  
24           the planning peak load. Notably, the NPCC constraint is not the only  
25           constraint that dictates how much capacity might be required on the system.  
26           Plexos’ ability to model hourly dispatch requirements means that any  
27           ramping requirements must be met with adequate capacity. Also, the  
28           presence of annual emissions constraints combined with the multi-fossil-  
29           fuel environment in which the thermal fleet operates (coal, oil, gas) leads to  
30           capacity requirements that could exceed thresholds needed to meet either  
31           NPCC reserve or ramping requirements. The integrated aspect of the model

---

<sup>44</sup> Synapse Energy Economic Inc., Nova Scotia Power Inc. Thermal Generation Utilization and Optimization Economic Analysis of Retention of Fossil-Fueled Thermal Fleet To and Beyond 2030 – M08059, filed on May 1, 2018.

**2021 10-Year System Outlook**  
**NON-CONFIDENTIAL**

---

1 (long-term planning and short-term dispatch) is intended to allow capture  
2 of all these moving parts when optimizing retirement and build decisions.<sup>45</sup>  
3

4 As noted by Synapse, other considerations may dictate the most economic generating  
5 capacity for the system; therefore, any surplus capacity in an outlook does not necessarily  
6 suggest that any full or partial unit retirement would be possible or optimal, as these units  
7 may provide other additional value. The optimal capacity requirements, including  
8 addressing a capacity shortfall and the appropriateness of any unit retirements, have been  
9 evaluated in the 2020 IRP and will be analyzed further as NS Power updates its long term  
10 planning analyses.

11  
12 The reference plan from the 2020 IRP (Scenario 2.0C) forms the planning basis for the  
13 2021 10-Year System Outlook.

---

<sup>45</sup> *Ibid* at Section 3.1.



**2021 10-Year System Outlook  
NON-CONFIDENTIAL**

1 **Figure 19: NS Power 10-Year Load and Resources Outlook**

<b>Load and Resources Outlook for NSPI - Winter 2021/2022 to 2030/2031 (All values in MW except as noted)</b>											
		<b>2021/ 2022</b>	<b>2022/ 2023</b>	<b>2023/ 2024</b>	<b>2024/ 2025</b>	<b>2025/ 2026</b>	<b>2026/ 2027</b>	<b>2027/ 2028</b>	<b>2028/ 2029</b>	<b>2029/ 2030</b>	<b>2030/ 2031</b>
<b>A</b>	Firm Peak including effects of DSM & DR <sup>46</sup>	2,062	2,065	2,060	2,053	2,049	2,046	2,044	2,044	2,047	2,057
<b>B</b>	Required Reserve (Ax20%)	412	413	412	411	410	409	409	409	409	411
<b>C</b>	Required Capacity (A+B)	2,475	2,478	2,472	2,463	2,459	2,455	2,453	2,453	2,457	2,468
<b>D</b>	Existing Resources (NS Power and IPPs) <sup>47</sup>	2,417	2,417	2,417	2,417	2,417	2,417	2,417	2,417	2,417	2,417
<b>E</b>	Existing Resources (Wholesale Market Resources) <sup>48</sup>	4	4	4	4	4	4	4	4	4	4
<b>F</b>	Total Existing Resources	2,421	2,421	2,421	2,421	2,421	2,421	2,421	2,421	2,421	2,421
	Firm Resource Additions:										
<b>G</b>	Thermal Additions <sup>49</sup>	43									
<b>H</b>	Thermal Retirements <sup>50</sup>	-148									
<b>I</b>											
<b>J</b>	Tidal <sup>51</sup>	2	1	1	1			2			
<b>K</b>	Hydro <sup>52</sup>		-108		101						
<b>L</b>	Maritime Link Import	153									
<b>M</b>	IRP Additions <sup>53</sup>	165	19			150				140	
<b>N</b>	IRP Retirements <sup>53</sup>		-150			-171				-168	
<b>O</b>	Total Annual Firm Additions (G+H+I+J+K+L+M+N)	215	-237	1	102	-21	0	2	0	-28	0
<b>P</b>	Total Cumulative Firm Additions (O+P of the previous year)	215	-23	-21	80	59	59	61	61	33	33
<b>Q</b>	Total Firm Capacity (F+P)	2,636	2,399	2,400	2,501	2,480	2,480	2,482	2,482	2,454	2,454
	+ Surplus/- Deficit (Q - C)	161	-80	-73	38	22	25	29	29	-3	-14
	Reserve Margin % [(Q - A)/A]	28%	16%	16%	22%	21%	21%	21%	21%	20%	19%

2

<sup>46</sup> Firm peaks as per 2021 Load Forecast including the effects of both DSM and DR programs as shown in Section 2.0, Figure 2.

<sup>47</sup> Existing Resources NS Power-owned and IPPs as shown in Section 3.1, Figure 3

<sup>48</sup> Existing Resources Wholesale Market Resources - resources managed by participants in the wholesale market as shown in Section 3.1, Figure 4.

<sup>49</sup> PH Biomass assumed to transfer to NRIS service in Q4 2021.

<sup>50</sup> Lingan 2 retirement/lay-up (- 148 MW) upon commencement of Maritime Link Base Block import (+ 153 MW)

<sup>51</sup> Tidal projects (firm capacity) forecast to be phased-in over the 10 years..

<sup>52</sup> Assumes ELCC 95% for hydro sites. Mersey is derated by 6.8 MW during anticipated rebuild work, refer to Section 3.1.2. Wreck Cove life extension modifications assumes one WC unit will be unavailable from June 2022 to July 2024, refer to Section 3.1.3. Solutions for any capacity shortfalls will be evaluated including access to firm capacity if required.

<sup>53</sup> Additions and Retirements as per the 2020 IRP Reference Plan (2.0C) shown in Section 3.2.1, Figure 6.


2021 10-Year System Outlook  
NON-CONFIDENTIAL

8.0 TRANSMISSION PLANNING

8.1 System Description

The existing transmission system has approximately 5,220 km of transmission lines at voltages at the 69 kV, 138 kV, 230 kV and 345 kV levels. The configuration of the NS Power transmission system and major facilities is shown in Figure 20.

Figure 20: NS Power Major Facilities in Service 2021



The 345 kV transmission system is approximately 468 km in length and comprises 372 km of steel tower lines and 96 km of wood pole lines.

**2021 10-Year System Outlook  
NON-CONFIDENTIAL**

---

1           The 230 kV transmission system is approximately 1,271 km in length and comprises 47  
2           km of steel/laminated structures and 1,224 km of wood pole lines.

3  
4           The 138 kV transmission system is approximately 1,871 km in length and comprises 303  
5           km of steel structures and 1,568 km of wood pole lines.

6  
7           The 69 kV transmission system is approximately 1,560 km in length and comprises 12  
8           km of steel/concrete structures and 1,548 km of wood pole lines.

9  
10          Nova Scotia is interconnected with the New Brunswick electric system through one 345  
11          kV and two 138 kV lines providing up to 505 MW of transfer capability to New Brunswick  
12          and between 0 and 300 MW of transfer capability from New Brunswick, depending on  
13          system conditions. As the New Brunswick system is interconnected with the province of  
14          Quebec and the state of Maine, Nova Scotia is integrated into the NPCC bulk power system.

15  
16          Nova Scotia is also interconnected with Newfoundland via a 500 MW, +/-200 kV DC  
17          Maritime Link tie that was placed into service on January 15, 2018 in preparation for the  
18          receipt of capacity and energy from the Muskrat Falls Hydro project and the Labrador  
19          Island Link DC tie between Labrador and Newfoundland. The Maritime Link is owned and  
20          operated by NSP Maritime Link Inc., a wholly owned subsidiary of Emera Newfoundland  
21          & Labrador.

22  
23      **8.2    Transmission Design Criteria**

24  
25          Consistent with good utility practice, NS Power utilizes a set of deterministic criteria for  
26          its interconnected transmission system that combines protection performance  
27          specifications with system dynamics and steady state performance requirements.

1       The approach used has involved the subdivision of the transmission system into various  
2       classifications, each of which is governed by the NS Power System Design Criteria. The  
3       criteria require the overall adequacy and security of the interconnected power system to be  
4       maintained following a fault on and disconnection of any single system component.

5  
6       **8.2.1 Bulk Power System (BPS)**

7  
8       The NS Power bulk transmission system is planned, designed and operated in  
9       accordance with North American Electric Reliability Corporation (NERC)  
10      Standards and NPCC criteria. NS Power is a member of the NPCC, therefore, those  
11      portions of NS Power’s bulk transmission network where single contingencies can  
12      potentially adversely affect the interconnected NPCC system are designed and  
13      operated in accordance with the NPCC Regional Reliability Directory 1: Design  
14      and Operation of the Bulk Power System, and are defined as Bulk Power System  
15      (BPS).

16  
17      **8.2.2 Bulk Electric System (BES)**

18  
19      The NERC Bulk Electric System BES definition encompasses any transmission  
20      system element at or above 100 kV with prescriptive inclusions and exclusions that  
21      further define BES. System Elements that are identified as BES elements are  
22      required to comply with all relevant NERC reliability standards.

23  
24      NS Power has adopted the NERC definition of the BES and an NS Exception  
25      Procedure for elements of the NS transmission system that are operated at 100 kV  
26      or higher for which contingency testing has demonstrated no significant adverse  
27      impacts outside the local area. The NS Exception Procedure is used in conjunction  
28      with the NERC BES definition to determine the accepted NS BES elements and is  
29      equivalent to Appendix 5C of the NERC Rules of Procedure.

1 The BES Definition and NS Exception Procedure were approved by NSUARB  
2 Order dated April 6, 2017.<sup>54</sup>

3  
4 Under the BES definition and NS Exception Procedure approved by the NSUARB,  
5 elements classified as NS BES elements are required to adhere to all relevant NERC  
6 standards that have been approved by the NSUARB for use in Nova Scotia.

### 8 **8.2.3 Special Protection Systems (SPS)**

9  
10 Special Protection Systems (SPS) are also referred to as Remedial Action Schemes  
11 (RAS) in NERC documentation. Both terms are valid.

12  
13 NS Power also makes use of SPS in conjunction with the Supervisory Control and  
14 Data Acquisition (SCADA) system to enhance the utilization of transmission assets.  
15 These systems act to maintain system stability and remove equipment overloads,  
16 post- contingency, by rejecting generation and/or shedding load. The NS Power  
17 system has several transmission corridors that are regularly operated at limits  
18 without incident due to these SPS.

### 19 20 **8.2.4 NPCC Directory 1 Review**

21  
22 A Working Group under the NPCC Task Forces on Coordination of Planning  
23 (TFCP) and Coordination of Operation (TFCO) has been created to conduct a  
24 review of the NPCC Directory 1 Document: Design and Operation of the Bulk  
25 Power System.

---

26  
<sup>54</sup> M06930, Nova Scotia Power Application for Approval of the NERC Bulk Electric System (BES) definition, the NS Power BES Exception Procedure, the BES Exception Request Form and NS Power's specific requests for exceptions from the BES, NSUARB Order, April 6, 2017.

**2021 10-Year System Outlook**  
**NON-CONFIDENTIAL**

---

1 Membership was solicited from the NPCC Task Forces on Coordination of Planning, and  
2 Coordination of Operation and other interested representatives of NPCC Member  
3 Companies.

4  
5 At present, Directory 1<sup>55</sup> provides a “design-based approach” to design and operate the  
6 bulk power system to a level of reliability that will not result in the loss or unintentional  
7 separation of a major portion of the system from any of the contingencies referenced. The  
8 objectives of the review are stated as follows:

9  
10 In accordance with the NPCC Directory Review and Revision Manual  
11 perform the periodic review of NPCC Directory #1 Design and Operation  
12 of the Bulk Power System. Considering the differing performance  
13 requirements and objectives of the NPCC criteria and NERC reliability  
14 standards, this review will:

15 1. Review landscape of Directory #1 related NERC reliability standards  
16 with focus on upcoming or proposed standard changes; e.g. "Establish and  
17 Communicate SOL Projects."

18 2. Review of Directory #1 related NERC standards and:

19 a. Assess incremental value of Directory #1 over NERC standards

20 b. Determine if revision(s) to NERC standards may support North  
21 American BES reliability and notify the Regional Standards  
22 Committee.

23 3. Review Directory#1 operating criteria to ensure consistency with NERC  
24 IROL and SOL requirements & terminology.

25 4. Identify any required changes based on increased penetration of  
26 distributed energy resources (“DER”) or unnecessary obstacles to the  
27 reliable deployment of DER.

28 5. Perform a cost effectiveness review on the planning and operating criteria  
29 in Directory#1 to identify potential alternatives that achieve the same  
30 reliability outcome.

31 6. Consider any NERC continent-wide efforts (e.g. SPIDERWG) to verify  
32 that proposed Directory #1 revisions align with those efforts.

---

<sup>55</sup> <https://www.npcc.org/program-areas/standards-and-criteria/regional-criteria/directories>

---

**2021 10-Year System Outlook**  
**NON-CONFIDENTIAL**

---

1           7. Consider and propose alternatives to the terms “significant adverse  
2           impact”, “local area”, and “small or radial portions of the system” in  
3           performance requirements for the contingencies of Table 1 and Table 3 that  
4           better align with NERC terminology and concepts.

5           8. Update Directory #1 to reflect the term Remedial Action Scheme  
6           (“RAS”), rather than Special Protection System (“SPS”).

7           9. Review Directory #1, R12 and consider clarification of when the  
8           application of a RAS is not an acceptable solution to meet system  
9           performance requirements.

10          10. Resolve Directory 1 and Directory 7 references to “applicable criteria.”  
11          Directory 1 could describe what is meant by “applicable criteria”, as noted  
12          in multiple spots in the revised Directory 7, or Directory 7 could replace  
13          “applicable criteria” with a more general reference to facilitating  
14          achievement of the intended performance outcome.

15          11. Consider whether specific guidance on loop flow assumptions need to  
16          be considered when establishing base cases and the associated transfers.

17          12. Review guidelines in Directory #1 Appendix B for consistency with  
18          Area Transmission Review presentation formats.

19          13. Consider mechanisms to enhance communication between Operations  
20          and Planning.

21          14. Consider the impact of increasing amounts of Variable Energy  
22          Resources (“VER”), e.g. wind and solar generation. Determine if there are  
23          obstacles or more effective and reliable approaches to VER deployment.

24          15. Ensure NPCC is not inhibiting the State and Provincial decarbonization  
25          goals while meeting reliability and resilience objectives.

26          16. Review relevance of Directory #1 appendices content.

27  
28          NS Power has representation from both Operations and Planning on the Directory 1  
29          Working Group that is performing the review. At this time, the Directory 1 Working Group  
30          anticipates the review will take approximately two years to complete.  
31

1   **8.3   Transmission Life Extension**

2  
3       NS Power has in place a comprehensive maintenance program on the transmission system  
4       focused on maintaining reliability and extending the useful life of transmission assets. The  
5       program is centered on detailed transmission asset inspections and associated prioritization  
6       of asset replacement (i.e. conductor line, poles, cross-arms, guywires, and hardware  
7       replacement).

8  
9       Transmission line inspections consist of the following actions:

- 10  
11       •       Visual inspection of every line once per year via helicopter, or via ground patrol in  
12       locations not practical for helicopter patrols.  
13       •       Foot patrol of each non-BPS line on a three-year cycle. Where a Lidar survey is  
14       requested for a non-BPS line, the survey will replace the foot patrol in that year.  
15       •       For BPS lines, Lidar surveys every two years out of three, with a foot patrol  
16       scheduled for the third year.

17  
18       These inspections identify asset deficiencies or damage and confirm the height above  
19       ground level of the conductor span while recording ambient temperature. This enables the  
20       NSPSO to confirm that the rating of each line is appropriate.

21  
22   **8.4   Transmission Project Approval**

23  
24       The transmission plan presented in this document provides a summary of the planned  
25       reinforcement of the NS Power transmission system. The proposed investments are  
26       required to maintain system reliability and security and comply with System Design  
27       Criteria and other standards. NS Power has sought to upgrade existing transmission lines  
28       and utilize existing plant capacity, system configurations, and existing rights-of-way and  
29       substation sites where economic.



1 Major projects included in the plan have been included on the basis of a preliminary  
2 assessment of need. The projects will be subjected to further technical studies, internal  
3 approval at NS Power, and approval by the NSUARB. Projects listed in this plan may  
4 change because of final technical studies, changes in the load forecast, changes in customer  
5 requirements or other matters determined by NS Power, NPCC/NERC Reliability  
6 Standards, or the NSUARB.

7  
8 **8.5 New Large load Customer Interconnection Requests**

9  
10 NS Power received a number of new large load requests in 2020 with respect to proposed  
11 commercial, mining, aquaculture and government projects ranging in size from 1-15 MVA.  
12 As a result, approximately 45 Preliminary Assessments were performed, leading to the  
13 completion of eight formal Load Impact Studies on both the transmission and distribution  
14 systems. Five Load Impact studies are also either in progress or yet to be initiated. In two  
15 instances, Preliminary Assessments determined that a Load Impact Study was not required.  
16 Not all these assessments translate into near-term load, as some projects have multi-year  
17 construction or are not completed.

18  
19 There have been five applications to serve new or upgraded hospital facilities. These  
20 facilities are now requiring two distribution feeder supplies, each fed from a different  
21 substation. Both supplies must be capable of feeding the entire hospital load. Under normal  
22 conditions, each feeder circuit carries approximately 50 percent of the load. Upon loss of  
23 one source, the load supplied by that circuit automatically transfers to the second circuit.  
24 Where an existing distribution feeder circuit supply exists, NS Power has assumed  
25 responsibility for system upgrades for the primary supply to the facility. However, the  
26 facilities are responsible for the full cost of the second supply and all system upgrades  
27 required to provide that supply.

1 **9.0 TRANSMISSION DEVELOPMENT 2020 TO 2030**

2  
3 Investments in transmission infrastructure can be affected by energy policy and the changing  
4 sources of energy and capacity. Proposed transmission development plans and projects are subject  
5 to reconsideration and alignment with current policy goals. Items described below are current as  
6 of the date of this report.

7  
8 **9.1 Impact of Proposed Load Facilities**

9  
10 As noted in Section 8.5 of this Report, there are a number of system upgrades required to  
11 serve load facilities greater than 1 MW that were proposed in 2019 and 2020. These  
12 projects have precipitated the need for the following system upgrades:

- 13
- 14 1. Construction of new 15/20/25 MVA, 138 kV-26 kV substation at 101W-Bowater.  
15 This substation is currently under construction with an expected completion date in  
16 2022.
  - 17 2. Advancement of upgrades to 69 kV line L-5021 supplying the 50V-Klondike  
18 Substation. The temperature rating of L-5021 was upgraded to 70°C in 2020.
  - 19 3. Construction of a new 25/33/42 MVA, 138 kV-25 kV substation in Stellarton in  
20 2020/21. The design of this substation is currently in progress.
  - 21 4. Replacement of the 15N-Willow Lane 15/20/25//28 MVA, 69 kV-25 kV  
22 transformer 15N-T3 in 2020/21. A replacement transformer was ordered in 2020  
23 and is scheduled to be installed in 2021.
  - 24 5. Replacement of the Trenton 15/20/25 MVA, 69 kV-25 kV transformer 50N-T63 in  
25 2020/21. A replacement transformer was ordered in 2020 and is scheduled to be  
26 installed in 2021.

**2021 10-Year System Outlook  
NON-CONFIDENTIAL**

---

- 1           6.       Installation of a second 25/33/42 MVA, 138 kV-25 kV transformer at 1N-Onslow  
2                   in 2022. Area load continues to be monitored to determine the appropriate timing  
3                   of this installation.
- 4           7.       Installation of a new 25/33/42 MVA, 138 kV-25 kV substation on Suzie Lake  
5                   Crescent in 2023. Property acquisition for this site is currently underway.
- 6           8.       Installation of a new 10MVA, 69-25 kV portable dead-front transformer on line L-  
7                   5510 required to provide a 25 kV supply to a new mine site in 2022/23.
- 8           9.       Refurbishment of the 6S-Terrace Street Substation following retirement of 4kV  
9                   source with a new 7.5/10/12.5 MVA, 69-12.5 kV transformer complete with two  
10                  new 12.5 kV feeder circuits in 2022/23 to accommodate reliability in the Sydney  
11                  area and to provide a second source to the Cape Breton Regional Hospital (CBRH)  
12                  facility. A capital contribution will be required of the CBRH for this work.

13

14   **9.2     129H-Kearney Lake Relocation**

15

16           In the 2020 10-Year System Outlook Report, NS Power reported the lease for the 129H  
17           Kearney Lake Road substation property had been extended on February 27, 2018 and was  
18           set to expire on December 31, 2022. NS Power had been advised that the property owner  
19           intended to develop the site and that further lease extensions. As such, NS Power planned  
20           to relocate the 129H-Substation from its present site to two land parcels located across the  
21           street which were purchased for this purpose in 1986 and 1988.

22

23           Detailed inspection of these two land parcels revealed that site development costs would  
24           higher than expected in order to grade the property and provide a suitable access route into  
25           the site for a mobile transformer unit. Subsequent negotiations with the owners of the  
26           existing site resulted the Company acquiring an option to swap the existing Kearney Lake  
27           Substation site (plus sufficient property to enable an expansion for a second transformer  
28           and new approach structure) with the NS Power-owned land parcels across the street. The  
29           owners of the Kearney Lake site are also prepared to extend the existing lease if required

1 in order to complete this option. This option also involves surrendering a small portion of  
2 the existing L-6038 right-of-way resulting in re-alignment of the 129H transmission  
3 approaches so that L-6038 will be in the same corridor as the existing L-5004.

4  
5 As a result of this new option, NS Power has suspended plans to build a new 129H Kearney  
6 Lake substation, and instead is developing a scope of work to remain at the existing site.

### 8 **9.3 Transmission Development Plans**

9  
10 Transmission development plans are summarized below. As noted above, these projects  
11 are subject to change. The majority of the projects listed are included in the 2021 Annual  
12 Capital Expenditure Plan. In addition, some of the timelines associated with the projects  
13 listed in 2021 continue to be impacted by the ongoing COVID-19 global pandemic.

#### 14 15 **2021**

- 16 • Complete 12 MVA Mount Hope 69 kV-25 kV substation in Dartmouth (carry-over  
17 from 2020).
- 18 • 5P 25 MVA Mobile Substation Replacement (carry-over from 2020).
- 19 • 101W-Port Mersey Expansion to include a new 138 kV-25 kV, 15/20/25 MVA  
20 transformer and two feeders (C0011261, carry-over from 2020).
- 21 • Deteriorated Transmission Structure replacements and upgrades (L-6539, L-6516,  
22 L-6020, L-5054)
- 23 • Replacement of 9W-B53 support structure (carry-over from 2020).
- 24 • Construction of a new 25/33/42 MVA, 138 kV-25 kV substation in Stellarton in  
25 2021/22.
- 26 • Replacement of the 15N-Willow Lane 15/20/25//28 MVA, 69 kV-25 kV  
27 transformer 15N-T3 in 2021.

**2021 10-Year System Outlook**  
**NON-CONFIDENTIAL**

---

- 1           •       Replacement of the Trenton 15/20/25 MVA, 69 kV-25 kV transformer 50N-T63 in  
2                   2021.
- 3           •       Transmission Right-of-Way Widening 69 kV to reduce the occurrence of edge and  
4                   off right-of-way tree contacts (Year 6 of 8).
- 5           •       Procure the existing 129H-Kearney Lake Substation site from existing property  
6                   owner in exchange for NS Power property on the other side of Kearney Lake Road  
7                   in 2021.

8  
9           **2022**

- 10          •       Installation of a second 25/33/42 MVA , 138 kV-25 kV transformer at 1N-Onslow.
- 11          •       Transmission Right-of-Way Widening 69 kV to reduce the occurrence of edge and  
12               off right-of-way tree contacts (Year 7 of 8).
- 13          •       Install New 138 kV Supply to 50V-Klondike and replace existing 69-25 kV  
14               transformer with new 15/20/25 MVA unit.

15  
16          **2023**

- 17          •       Installation of a new 25/33/42 MVA, 138 kV-25 kV substation on Suzie Lake.
- 18          •       Transmission Right-of-Way Widening 69 kV to reduce the occurrence of edge and  
19               off right-of-way tree contacts (Year 8 of 8).

20  
21          **2026**

- 22          •       Replace transformers 62N-T1 and 62N-T2 at end of expected life with a single  
23               138/69 kV-25 kV, 15/20/25 MVA transformer.
- 24          •       Add a second 25/33/42 MVA, 138 kV-25 kV transformer at new Stellarton  
25               substation.

26  
27

1       **2028**

- 2       •       Installation of a new 138/69 kV-25 kV, 15/20/25 MVA substation in Lower Truro  
3               tapped to Line L-5028.

4

5   **9.4   Western Valley Transmission System – Phase II Study**

6

7       A study was initiated in late 2017 to determine the system upgrades needed to address  
8       transmission line capacity, clearance, and age issues in the Western Valley over a 15-year  
9       transmission planning horizon. In particular, the following 69 kV lines were targeted:

- 10
- 11           •       L-5531 (13V-Gulch to 15V-Sissiboo)
  - 12           •       L-5532 (13V-Gulch to 3W-Big Falls)
  - 13           •       L-5535 (15V-Sissiboo to 9W-Tusket)
  - 14           •       L-5541 (3W-Big Falls to 50W-Milton)

15

16       The scope of the study is to assess the following five options:

- 17
- 18       Option 1 -     Restore L-5531, L-5532, L-5535, and L-5541 to 50°C Temperature Rating
  - 19       Option 2 -     Upgrade L-5531, L-5532, L-5535, and L-5541 to 80°C Temperature Rating
  - 20       Option 3 -     Rebuild L-5531, L-5532, L-5535, and L-5541 with 336 ACSR Linnet and  
21                       100°C Temperature rating
  - 22       Option 4 -     Rebuild L-5531, L-5532, L-5535, and L-5541 with 556 ACSR Dove and  
23                       100°C Temperature rating (Operate at 69kV)
  - 24       Option 5 -     Bypass L-5025, L-5026, L-5531, and L-5535 with a new 138 kV line from  
25                       51V-Tremont to new substations at 13V-Gulch and 9W-Tusket

26

27       Status: Work on the Western Valley Transmission System – Phase II Study is anticipated  
28       to be completed by early Q3 2021.

1   **10.0   PANDEMIC RESPONSE**

2  
3   As a result of the response to the COVID-19 global pandemic, Nova Scotia Power has experienced  
4   slight shifts in the timing and ramping of peak load. The impacts on load continue, with an increase  
5   in residential load and a decrease in commercial load compared to prior years as a result of the  
6   pandemic. Weather remains the main driver of load profiles. The effects of the COVID-19  
7   pandemic on load patterns, energy usage, and peak demands will continue to be evaluated as the  
8   situation unfolds.

9  
10   NS Power has created and enacted system operator contingency plans to ensure health and safety  
11   of personnel and continued reliable operation of the power grid. The Company is evaluating  
12   contingency plans for T&D and Generation planned work, planned maintenance, and forced  
13   outages to proceed conservatively while mitigating short-term and longer term reliability risks.  
14   Contingency plans have continued to be evaluated over the course of the pandemic.

15  
16   NS Power continues to monitor the ongoing spread of COVID-19 and remains focused on the  
17   health and safety of employees, consultants, contractors, and their families. A response team is  
18   monitoring the situation, coordinating with authorities, and keeping employees informed via  
19   regular business updates.

1 **11.0 CONCLUSION**

2  
3 Customers count on NS Power for energy to power every moment of every day, and for solutions  
4 to power a sustainable tomorrow. Environmental legislation and policy initiatives in Canada and  
5 Nova Scotia have driven and will continue to drive transformation of the NS Power electric power  
6 system.

7  
8 As discussed in Section 10.0 above, NS Power continues to monitor the ongoing spread of COVID-  
9 19 and the impacts of the pandemic.

10  
11 The Company is currently forecasting a capacity deficit from 2022 until 2024. Solutions for any  
12 capacity shortfalls will be evaluated, including access to firm capacity if required. NS Power will  
13 continue to monitor potential deficits or apparent surpluses as forecasts continue to evolve and will  
14 adjust decisions accordingly.

15  
16 The key inputs for Transmission Planning in the 10-year window of this report include the impact  
17 of proposed new load facilities outlined in Section 9.1, transmission of energy to be delivered over  
18 the Maritime Link, and continued compliance with Reliability Standards.

19  
20 The 2020 IRP evaluated a robust set of future planning scenarios, with modeling assumptions that  
21 were created with comprehensive stakeholder input. Section 7.2 provides the detailed analysis of  
22 the PRM assumption that was evaluated in the 2020 IRP. As discussed in Section 7.3 the 2020 IRP  
23 evaluation has provided an updated ELCC for existing and new wind. The reference plan from the  
24 2020 IRP (Scenario 2.0C) forms the planning basis for the 2021 10-Year System Outlook and is  
25 the reference for the current Steam Fleet Retirement schedule as shown in Section 3.2.1, the current  
26 Unit Utilization and Investment Strategy as discussed in Section 3.3 and the foundation for the  
27 Load and Resources Review found in Section 7.4. For energy forecasting purposes, updated  
28 PLEXOS modeling for the initial three years 2022-2024 was completed and the reference plan  
29 from the 2020 IRP (Scenario 2.0C) provides the data for the period of 2025-2031.

30



**2021 10-Year System Outlook**  
**NON-CONFIDENTIAL**

---

1 Given the recent announcements by the Federal Government of its intention to cease all coal-fired  
2 electricity generation by 2030 and to increase the cost of GHG emissions by increasing the carbon  
3 price, as well as the announcement by the Government of Nova Scotia to implement a renewable  
4 energy standard of 80 percent it is anticipated that NS Power will experience significant changes  
5 over the 10-year period considered in this report.

6  
7 As these changes are better understood through legislative and regulation changes, these changes  
8 will be used inform future 10-Year System Outlook Reports and related long-term planning  
9 processes.